

STATE OF INDIANA

MAR 1 0 2008

INDIANA UTILITY

INDIANA UTILITY REGULATORY COMMISSION

REGULATORY COMMISSION

PETITION OF L.M.H. UTILITIES CORP. FOR AUTHORITY TO CHANGE ITS RATES, CHARGES, TARIFFS, RULES AND REGULATIONS.

CAUSE NO. 43431

PREFILED DIRECT TESTIMONY OF **CHRISTOPHER A. LIMCACO**

On behalf of

L.M.H. UTILITIES CORP.

PREFILED DIRECT TESTIMONY OF CHRISTOPHER A. LIMCACO ON BEHALF OF L.M.H. UTILITIES CORP. CAUSE NO. 43431

1	1	Q.	PLEASE STATE YOUR NAME AND BUSINESS ADDRESS.
2		A.	My name is Christopher A. Limcaco. My business address is 1426 West
3			29 th Street, Suite 206, Indianapolis, IN 46208.
4	2	Q.	MR. LIMCACO, DO YOU HOLD ANY LICENSES WHICH ARE
5			RELEVANT TO YOUR TESTIMONY HERE?
6		A.	Yes. I am a licensed professional engineer registered in the States of
7			Indiana, Illinois, and Kentucky.
8	3	Q.	DO YOU ALSO HOLD ANY DEGREES OR HAVE YOU HAD ANY
9			PROFESSIONAL EXPERIENCE WHICH IS RELEVANT TO
10			YOUR TESTIMONY HERE?
11		A.	Yes, I hold a B.S. Degree in Civil Engineering and an A.S. Degree in
12			Building Construction Technology from Purdue University. Since 1992, I
13			have been involved in the design, permitting, construction, and operation
14			of wastewater collection and treatment facilities throughout the Midwest.
15			These projects have run the gamut from large regional or municipal style
16			facilities to small industrial facilities. Since 2001, I have also been
17			involved with various business enterprises focused on developing,
18			designing, constructing, and operating innovative wastewater treatment
19			facilities. I have patented and have patents pending on an innovative
20			wastewater to energy system called Algicity.

4 Q. WHAT IS ALGICITY?

A.	Conventional wastewater treatment plants have traditionally been installed
	for a single purpose – cleaning wastewater to acceptable levels prior to
	discharge into the environment. Wastewater has historically been
	viewed as a waste product but I believe it has potential as a renewable
	energy resource. After visiting different types of wastewater treatment
	plants across the United States, I noticed something that was common in
	all of them – algae was always growing where the water was discharged
	back into the environment. The algae was growing at the wastewater
	plants due to the remaining nutrients in the water (the same reason for
	eutrophication of streams and lakes). I decided to incorporate algae into a
	wastewater treatment process and have since obtained three patents on the
	process. A significant advantage of using algae is the fact that algae
	produce oxygen and use CO2. This allowed a 50% reduction in the power
	requirements of the wastewater treatment process since solar energy was
	being used to pump oxygen into the wastewater instead of mechanical
	blowers. An additional aspect of using algae is its potential as a
	renewable energy source. The U.S. Department of Energy has determined
	that algae is capable of producing thousands of times the amounts of
	biodiesel as can be produced from terrestrial crops like soybeans. The
	algae also have a high heating value when combusted and can be used to
	generate electricity. The patent pending Algicity system uses algae to
	treat wastewater. The algae grown from the wastewater is harvested,

1			dried and burned in a combustion system to generate electricity. The CO2
2			emissions from the combustion system are recycled back into the
3			wastewater to grow additional algae. By reinvesting the CO2 emissions, I
4			believe a significant amount of energy can be produced from this
5			wastewater process. I would also note that this process also has no
6			greenhouse gas emissions since the emissions are continuously recycled
7			back to the wastewater process.
8	5	Q.	IN WHAT CAPACITY HAVE YOU BEEN RETAINED BY THE
9			PETITIONER IN THIS PROCEEDING?
10		A.	Following the Commission's order in Cause 43022, I was asked to assist
11			in valuing Petitioner's current wastewater collection and treatment
12			facilities. I was also asked to address the issue of whether the most recent

6 Q. MR. LIMCACO, HAVE YOU BEEN ABLE TO ESTABLISH THAT
PETITIONER'S PLANT IS BOTH USED AND USEFUL?

addition to the wastewater treatment plant was both used and useful in

meeting the needs of Petitioner's customers. Finally, the president asked

me to assist the other consultants in this proceeding in working with the

OUCC on various issues described in the Commission's Order of 43022.

A. Yes, I have. I believe that the Petitioner needed to make the expansion because the Petitioner's plant was unable to handle additional loadings to the plant above the current demand and did not have adequate redundancy for the current demand. Specifically, the influent raw sewage pump station at any wastewater treatment facility must be designed to handle

21

22

23

peak hydraulic conditions as well as have backup pump capacity in the event of mechanical failure. L.M.H.'s raw sewage station had neither and caused sewage to backup in the sewer system. The old raw sewage screen was undersized and caused undesirable solids to pass to the main aeration system causing significant operational problems. The plant also had inadequate sludge handling capabilities. As a result, in order to properly process the sludge generated by the plant, a portion of the main wastewater treatment system had to be removed from process treatment to sludge treatment and therefore reduced the normal process flow capacity of the plant. The current average daily flow to the plant was 94% of the capacity of the plant and the peak daily flow to the plant was over the capacity of the plant. Therefore, the plant had no additional capacity for future growth and was unable to adequately handle peak flow conditions prior to the last plant expansion. In fact, IDEM will put a facility on sewer ban when the flows reach 90% of the design flow at which level L.M.H. had already exceeded.

7 Q. MR. LIMCACO, IS YOUR OPINION AS TO THE NEED FOR THE EXPANSION SUPPORTED BY ANY OTHER ENGINEERING EVALUATIONS?

A. Yes, it is. Prior to my involvement with L.M.H. Utilities, the company sought and obtained an evaluation from RNK Environmental, Inc., an engineering firm located in northern Kentucky. The evaluation by that engineering firm included its recommendation that L.M.H. begin the

1			process of adding additional capacity to bring the facility up to
2			approximately 500,000 gallons per day of average design flow capacity.
3	8	Q.	DID L.M.H. INITIATE IMPROVEMENTS TO ITS WASTEWATER
4			TREATMENT PLANT IN ORDER TO INCREASE ITS FLOW AS
5			RECOMMENDED BY R.N.K. ENVIRONMENTAL?
6		A.	Yes, though I would note that the added capacity in fact brought the total
7			average design flow capacity up to 480,000 gallons per day.
8	9	Q.	WHY WAS THE WASTEWATER TREATMENT PLANT
9			EXPANDED TO 480,000 GPD?
10		A.	L.M.H. utilizes a Sequential Batch Reactor (SBR) wastewater treatment
11			process which includes one main process tank divided into two sections.
12			The process tank is rated at 240,000 gpd. The SBR process uses a timer
13			controlled sequencing system and in order for the process to work, the
14			tanks must be the same size for equal flow and loading distribution.
15			Therefore, a duplicate tank arrangement was necessary to match the
16			existing increasing the capacity of the main process to 480,000 gpd.
17	10	Q.	MR. LIMCACO, YOU HAVE PREVIOUSLY INDICATED THAT
18			YOU WERE ASKED TO PROVIDE A VALUE OF THE
19			PETITIONER'S CURRENT PLANT. HAVE YOU DONE SO?
20		Α.	Yes.
21	11	Q.	ISN'T IT TRUE THAT PETITIONER'S PLANT HAS BEEN
22			CONSTRUCTED IN PHASES AT DIFFERENT TIMES?
23		A.	Yes, that is true.

1	12 Q	HOW CAN YOU PROVIDE AN APPROPRIATE VALUE FOR
2		PETITIONER'S PLANT IN LIGHT OF THE FACT THAT IT WAS
3		CONSTRUCTED IN PHASES?
4	A.	With knowledge of the actual elements of the facilities which have been
5		constructed, and the year in which they were constructed, the value can be
6		calculated for both current replacement costs, and through the Handy-
7		Whitman Index calculated as of the time actually installed. Thereafter,
8		you can depreciate both current replacement costs, as well as the Handy-
9		Whitman costs. Finally, there are a number of ways in which your
10		resulting numbers can be checked for reasonableness.
11	13 Q	. HAVE YOU MADE THOSE CALCULATIONS AND CHECKED
12		YOUR CONCLUSIONS FOR REASONABLENESS?
13	A.	Yes, I have
14	14 Q	. HAVE YOU PROVIDED THIS COMMISSION WITH EXHIBITS
15		WHICH REFLECT THE VALUE OF REPLACEMENT COST
16		NEW, THE ORIGINAL COST CALCULATED VIA THE HANDY-
17		WHITMAN INDEX, AND THE COST CHECKS?
18	A.	Yes, attached are the following Exhibits:
19		CAL-1. Table 1 – Current Replacement Cost (Replacement Cost
20		New)
21		CAL-2. Table 2 – Original Cost (Handy-Whitman Original Cost)
22		CAL-3. Table 3 – WWTP Replacement Cost Using Current Low
23		Bid Cost Information

1	CAL-4. Table 4 – Actual WWIP Construction Costs in Indiana
2	CAL-5. Table 5 – Summary of Treatment Plant Results
3	CAL-6. Figure 1 – New WWTP Construction Costs in Indiana
4	CAL-7. Figure 2 – WWTP Expansion Construction Costs in
5	Indiana
6	Q. HAVE YOU ALSO RECOGNIZED DEPRECIATION IN THOSE
7	VALUES?
8	A. Yes.
9	16 Q. PLEASE WALK US THROUGH THE CALCULATIONS THAT
0	YOU HAVE MADE.
.1	A. Utilizing available maps, records, specifications, reports, discussions with
2	the Owner, and site visits, a detailed itemized components list of the
3	Owners' existing wastewater facilities was developed and is summarized
14	in Table 1 and Table 2. For aid in review, the list was divided into two
15	sections. The first section included the collection system (ie. lift stations,
16	gravity sewers, manholes, and force mains), and the second section
17	included the wastewater treatment plant. Each Table includes a
18	description of each item, size of each item, quantity of each item, and the
19	date the item was constructed. For example, Line 1 in Table 1 and Table
20	2 shows that Lift Station #1 was a 2 horsepower pump station installed in
21	1989.

Due to the absence of reliable records reflecting actual construction costs

its useful life remaining.

for the facilities, estimates of the 2007 replacement cost for each component was made based on my experience and judgment. Continuing with the previous example, Lift Station #1 was estimated to have a 2007 replacement cost of \$25,000 based on its size.

A typical design life for each component was assigned for the valuation. In the example, Lift Station #1 is estimated to have a design life of 25 The installation date and the design life of the items was then used to calculate the useful life remaining (as a percentage) for each item. In the example, Lift Station #1 was installed in 1989 and has a useful life of 25 years. Therefore, Lift Station #1 is 18 years old (2007 minus 1989)

and has 7 years of useful life remaining (25 year design life minus 18 years old). In other words, Lift Station #1 has 28% (7 years/25 years) of

The first valuation method (Table 1) calculated the "Total Estimated Current Value" of each item by multiplying the useful life remaining by the 2007 replacement cost. In the example for Lift Station #1, the Total Estimated Current Value would be calculated as $25,000 \times 0.28 = 7,000$.

21

19

20

Finally, all of the items were summed to give a Total Estimated Current Value less depreciation for the collection system and treatment plant of \$6,133,587 and \$2,002,098 respectively.

The second valuation method (Table 2) used the Handy-Whitman index for the installed year and the Handy-Whitman index for 2007 (as a percentage) to calculate the original cost of each item. Continuing with the Lift Station #1 example, the Handy-Whitman index for the year that Lift Station #1 was installed (1989) was 296 and the Handy-Whitman index for year 2007 was 557. The Total Estimated Original Cost is calculated by multiplying the 2007 Replacement Cost by the ratio of the two Handy-Whitman indexes. For Lift Station #1 the Original Cost is $$25,000 \times (296/557) = $13,275$ (rounded). Based on the useful life remaining for each item, the "Original Cost Net of Depreciation" was then calculated by multiplying the useful life remaining by the Original Cost. For Lift Station #1, the Original Cost Net of Depreciation is calculated as $$13,275 \times 0.28 = $3,717$.

Finally, all of the items were summed, as was done for replacement cost less depreciation, to give a Total Original Cost Net of Depreciation for the collection system and treatment plant of \$3,712,874 and \$1,765,998 respectively.

Q. MR. LIMCACO, YOU INDICATED EARLIER THERE WERE WAYS TO CHECK THE REASONABLENESS OF THESE RESULTS. PLEASE DESCRIBE THE CHECKS OF REASONABLENESS THAT YOU MADE.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

The construction costs for several wastewater treatment plant projects recently bid were compiled to develop a typical unit cost for wastewater treatment plants in Indiana (Table 4). The data was further broken down into new plant construction and plant expansions since those costs are significantly different for the two types. The unit costs for the new plant construction developed in Table 4 were then plotted on a graph (Figure 1) with flow capacity shown on the "X" axis versus cost per gallon shown on the "Y" axis. A standard regression analysis was performed to develop a best fit curve for the data. From this curve, the unit prices for L.M.H.'s new plants could be derived. For example, L.M.H.'s first wastewater treatment plant was a new 20,000 gpd or 0.02 million gallons per day (MGD) plant. Starting at 0.02 MGD on the "X" axis and going up to the line shown in red to the curve gives a cost per gallon of \$25/gal. The same analysis that was performed on the new plants was performed for the plant expansions and is shown in Figure 2. For example, L.M.H.'s third plant expansion was a 0.2 MGD plant expansion shown by the red line which corresponds to an \$8.60/gal unit cost. The resulting unit costs developed from Figures 1 and 2 were then used to calculate the 2007 replacement costs for each new plant and plant expansion as shown in

	1			
	2			
	3			
	4			
	5			
	6			
	7			
	8			
	9			
	0			
1	1			
1	2			
1	3			
1	4			
1	5			
1	6			
1	7			
1	8			
1	9			
2	0			

22

Table 3. Using the previous 20,000 gpd example, the 2007 replacement cost is calculated as 20,000 gpd x \$25/gal = \$500,000. Likewise, the 2007 replacement cost for the 0.2 MGD plant expansion in the previous example would be 200,000 gpd x 88.60/gal = \$1,720,000. The "Total Estimated Current Value" of each plant expansion was calculated in the same manner as Table 1 and Table 2 discussed previously by multiplying the useful life remaining by the 2007 replacement cost. In the example for the 20,000 gpd plant, the Total Estimated Current Value would be calculated as $$500,000 \times 0 = 0 . In the example for the 200,000 gpd plant expansion, the Total Estimated Current Value would be calculated as $$1,720,000 \times 0.35 = $602,000$. Finally, all of the items were summed to give a Total Estimated Current Value of the treatment plant of \$2,267,700.

Q. MR. LIMCACO, A NUMBER OF THE ENTITIES THAT YOU REFERENCE ABOVE (TABLE 4) APPEAR TO BE MUNICIPAL ENTITIES. DO YOU KNOW WHETHER OR NOT THOSE MUNICIPAL ENTITIES BID THOSE PROJECTS?

A. All of the entities were municipalities or political subdivisions of the state.

Thus, all of the projects listed were publically bid. In each case, the project was given to the lowest responsible and responsive bidder pursuant to Indiana state statute. I obtained the bid tabulations for each project and used the awarded bid numbers in my check.

1	19 Q. MR. LIMCACO, DOES THE CHECK THAT YOU MADE USING
2	ACTUAL BIDS SUPPORT THE VALUE THAT YOU ARE
3	RECOMMENDING FOR THE L.M.H. PLANT?
4	A. Yes, it does. Table 5 is a summary of the treatment plant value
5	developed from the three different methods. The Total Estimated Current
6	Value (less depreciation) or Original Cost Net of Depreciation for
7	methods 1 and 2 WERE \$2,002,098 and \$1,765,998, respectively. The
8	cost derived from the actual construction cost data less depreciation
9	(Method 3) \$2,267,600, was close but higher than the two detailed cost
10	methods. This indicates that we were both conservative and accurate in
11	our original detailed cost estimates. In addition, the bid tabulation costs
12	do not include soft construction costs such as design, legal, and

14

15

16

17

18

19

20

21

20 Q. WHAT IS YOUR OPINION OF THE VALUE OF PETITIONER'S USED AND USEFUL PLANT IN SERVICE?

here would have been higher.

permitting which L.M.H. incurred on each plant expansion. Soft

construction costs are typically 20-25% of the construction costs on

projects of similar size and scope as the L.M.H. projects. Had these soft

costs been capitalized as part of the value of the plant, the value described

A. Without considering the soft costs incurred, I believe the value of L.M.H.'s plant in service is between \$5,538,873 and \$8,195,685.

1		21	Q.	TOO MENTIONED EARLIER THAT TOO WERE ASKED TO
2				WORK WITH THE OUCC. WOULD YOU DESCRIBE THAT
3				WORK.
4			A.	I met with the OUCC staff, including its engineers, accountants, and
5				financial analysts, to discuss how I had analyzed Petitioner's existing
6				plant. I explained each calculation I made and provided various
7				information to the OUCC. I described the various checks for
8				reasonableness I made. I answered a number of questions and posed a
9				number of questions to the OUCC about alternative approaches.
10		22	Q.	DO YOU BELIEVE THIS COLLABORATIVE APPROACH WAS
11				HELPFUL?
12			A.	Yes, I do. By exchanging information with the OUCC and considering
13				various issues, I was able to refine my opinion. The result I believe is a
14				reasonable fair value allocated to Petitioner's plant in service, currently
15				used and useful, as well as necessary for service to Petitioner's customers
16		23	Q.	DOES THIS CONCLUDE YOUR TESTIMONY
17 18 19			A.	Yes, it does.
20	1103109			

CAL-1. Table 1 – Current Replacement Cost (Replacement Cost New)

TABLE 1: CURRENT REPLACEMENT COST

20,000 gpd plant 100,000 gpd plant 200,000 gpd expansion (300,000 gpd capacity) 180,000 gpd expansion (480,000 gpd capacity)

Phase 1 1987
Phase 2 1990
Phase 3 1994
Phase 4 2006

Replacement Cost Less Depreciation

										nent Cost Less De	
			l				2007 Replacement	Year	Design	Useful Life	Total Est.
		ltem	Unit	Quantity	Unit Cost		Total Cost	Installed	Life (years)	Remaining	Current Valu
		Lift Station #1 - Picnic Woods/Big Water Dr/Apple Ct - 2 hp	ls	1	\$	25,000		1989	25	0.28	\$ 7,00
		Lift Station #2 - Bright Ridge Pump Station - 5 hp	ls	1	\$	30,000		1993	25	0.44	\$ 13,20
	Γ	Lift Station #3 - Pontiac/Carr Rd - 5 hp	ls	1	\$	30,000	\$ 30,000	1995	25	0.52	\$ 15,60
		Lift Station #4 - Lamplight/Picnic Wood Sec 10 - 2 hp	ls	1	\$	25,000	\$ 25,000	1996	25	0.56	\$ 14,00
		Lift Station #5 - Provident Development Downtown to American State Bank - 2	ls	1	\$	25,000	\$ 25,000	1997	25	0.60	\$ 15,00
	92	Lift Station #6 - Timber Ridge/Redwood Dr/Heartland Heights/Salt Ford Rd - 5	ls	1	\$	30,000	\$ 30,000	1998	25	0.64	\$ 19.20
	Lift Stations	Lift Station #7 - Seldom Seen III/Hunters Crossing/Sandstone Dr - 5 hp	ls	1	\$	30,000		1999	25	0.68	\$ 20.40
	78	Lift Station #8 - Southpoint Condo's - 5 hp	ls	1	\$	30,000		2000	25	0.72	\$ 21,60
	. ซี -	Lift Station #9 - Old Orchard/Apple Blossom - 40 hp	ls	 	\$	100,000		2002	25	0.80	\$ 80,0
	# +	Lift Station #10 - Brookstone - 20 hp	ls	 	\$	80,000		2002	25	0.80	\$ 64,0
					\$	25,000		2002	25	0.80	\$ 20.0
		Lift Station #11 - Brookstone - 2 hp	ls	1	-						
	L	Lift Station #12 - Saltfork to Brightwood Dr - 7 hp	ls	1	\$	45,000		2002	25	0.80	\$ 36,0
		Lift Station #13 - Park Place - 7 hp	ls	1 1	\$	45,000		2003	25	0.84	\$ 37,8
	L	Lift Station #14 - Ingham Mills/Hekk Dev - 5 hp	ls	1	\$	30,000		2003	25	0.84	\$ 25,2
		Lift Station #15 - Jamison Place Condo - 3 hp	ls	1	\$	25,000	\$ 25,000	2005	25	0.92	\$ 23,0
		4" pipe									
		timber ridge/redwood dr/heartland heights/salt ford rd	lf	2,900	\$	25.00	\$ 72,500	1998	50	0.82	\$ 59,4
	Γ	8" pipe (average 7' depth)									
		picnic woods dr. jamison dr to picnic woods dr. main to plant	lf	7,023	\$	50.00	\$ 351,150	1987	50	0.60	\$ 210.6
	F	picnic woods/renck ct/siefferman ct	lf	1,420	\$	50.00		1988	50	0.62	\$ 44,0
	ŀ	picnic woods/big water dr/apple ct	lf	7,964	\$	50.00		1989	50	0.64	\$ 254,8
100		picnic woods/gabbard/gibson/vineyard	lf	3,670	\$	50.00		1990	50	0.66	\$ 121,
	H	cedar ridge	lf	906	\$	50.00		1991	50	0.68	\$ 30,8
1940.5	· · · · · · · · · · · · · · · · · · ·		lf	5,555	\$		\$ 277,750	1992	50	0.70	\$ 194,4
	-	picnic woods/judd/strother									
4.00		bright ridge	lf	7,669	\$	50.00		1993	50	0.72	\$ 276,0
	le de la	lela	lf	3,260	\$	50.00		1993	50	0.72	\$ 117,3
	L	seldom seen and brightwood	lf	8,760	\$	50.00		1994	50	0.74	\$ 324,1
41,546	- 5 L	pontiac/carr rd	lf	2,707	\$	50.00		1995	50	0.76	\$ 102,8
10.0	Sewer	lamplight/picnic wood sec 10	lf	1,450	\$	50.00		1996	50	0.78	\$ 56,5
	. vi	christian church/bright vet	lf	1,415	\$	50.00	\$ 70,750	1996	50	0.78	\$ 55,1
1	Gravity	picnic woods sec 10	lf	2,285	\$	50.00	\$ 114,250	1997	50	0.80	\$ 91,4
	6 [provident development downtown bright to american state bank	lf	1,066	\$	50.00	\$ 53,300	1997	50	0.80	\$ 42,6
i	5 T	bright business center	Lf	1.865	\$	50.00	\$ 93,250	1997	50	0.80	\$ 74,6
		timber ridge/redwood dr/heartland heights/salt ford rd	lf .		\$	50.00		1998	50	0.82	\$ 121,9
	The F	seldom seen III/hunters crossing/sandstone dr	lf		\$	50.00		1999	50	0.84	\$ 86,
	F	southpoint condos	lf		\$	50.00		2000	50	0.86	\$ 126,8
		grote/trading post	l (f		\$	50.00		2000	50	0.86	\$ 9,4
			lf		\$		\$ 37,500	2000	50	0.86	\$ 32,
	- L	trade line									
	L	old orchard/apple blossom	lf		\$	50.00		2002	50	0.90	\$ 527,4
1989		brookstone	lf		\$		\$ 499,000	2002	50	0.90	\$ 449,
	L	dawn paul dr/grubbs 3	lf		\$		\$ 50,000	2002	50	0.90	\$ 45,
	L	saltfork to brightwood dr	lf		\$		\$ 109,050	2002	50	0.90	\$ 98,
	L	park place	lf		\$	50.00	·	2003	50	0.92	\$ 288,
		ingham mills/hekk dev	lf	20	\$	50.00	\$ 1,000	2003	50	0.92	\$
Σ	- Γ	jamison place condo	lf	2,200	\$	50.00	\$ 110,000	2005	50	0.96	\$ 105,
4		picnic woods dr, jamison dr to picnic woods dr, main to plant	ea	20	\$:	2,000.00	\$ 40,000	1987	50	0.60	\$ 24,
2	/ T	picnic woods/renck ct/siefferman ct	ea	4	\$:	2,000.00	\$ 8,000	1988	50	0.62	\$ 4,
n	T. T.	picnic woods/big water dr/apple ct	ea	20		2,000.00		1989	50	0.64	\$ 25,
z I		picnic woods/gabbard/gibson/vineyard	ea	7		2,000.00		1990	50	0.66	\$ 9.
2 ∣		cedar ridge	ea	3		2,000.00		1991	50	0.68	\$ 4.
5						2,000.00		1994	50	0.74	\$ 34.
<u> </u>	, , , , , , , , , , , , , , , , , , ,	seldom seen and brightwood	ea								
1	L	pontiac/carr rd	ea	7		2,000.00		1995	50	0.76	\$ 10,
२	L	lamplight/picnic wood sec 10	ea	12		2,000.00		1996	50	0.78	\$ 18,
ATER COLLECTION SYSTEM	ு ப	christian church/bright vet	ea	7		2,000.00		1996	50	0.78	\$ 10,
<u> </u>	holes	provident development downtown bright to american state bank	ea			2,000.00		1997	50	0.80	\$ 11,3
- 1	Z T	bright business center	ea	20	\$:	2,000.00	\$ 40,000	1997	50	0.80	\$ 32,

TABLE 1: CURRENT REPLACEMENT COST

20,000 gpd plant 100,000 gpd plant 200,000 gpd expansion (300,000 gpd capacity) 180,000 gpd expansion (480,000 gpd capacity)

Phase 1 1987 Phase 2 1990 Phase 3 1994 Phase 4 2006

Replacement Cost Less Depreciation

										nent Cost Less De		
			ł				2007 Replacement	Year	Design	Useful Life		tal Est.
		Item	Unit	Quantity	U	nit Cost Data	Total Cost	Installed	Life (years)	Remaining	Curre	ent Value
3	Mair	seldom seen III/hunters crossing/sandstone dr	ea	7	\$	2,000.00	\$ 14,000	1999	50	0.84	\$	11,76
WASTEW	2	southpoint condos	ea	7	\$	2,000.00	\$ 14,000	2000	50	0.86	\$	12,04
Ŋ		grote/trading post	ea	3	\$	2,000.00	\$ 6,000	2000	50	0.86	\$	5,16
\$		trade line	ea	2	\$	2,000.00	\$ 4,000	2000	50	0.86	\$	3,44
	100	old orchard/apple blossom	ea	36	\$	2,000.00		2002	50	0.90	\$	64,80
		brookstone	ea	23	\$	2,000.00		2002	50	0.90	\$	41,40
		dawn paul dr/grubbs 3	ea	4	\$	2,000.00		2002	50	0.90	\$	7.20
		saltfork to brightwood dr	ea	7	\$	2,000.00		2002	50	0,90	\$	12,60
	100000000000000000000000000000000000000			20	\$	2,000.00		2002	50	0.70	\$	36,80
		park place	ea	7	\$			2005	50	0.96	\$	13,44
		jamison place condo	ea		1.7	2,000.00	\$ 14,000	2005	50	0.70	₽	13,44
		1.5" force main	 	1500	 	45.00	# 00 F00	4007	<u> </u>			48.55
		lamplight/picnic wood sec 10	lf	1,500	\$	15.00	\$ 22,500	1996	50	0.78	\$	17,55
		2" force main			<u> </u>		·				ļ	
		mt meadows	lf	1,720	\$	15.00		1993	50	0.72	\$	18,57
		pontiac/carr rd	lf	1,640	\$	15.00		1995	50	0.76	\$	18,69
		brightwood/maple ridge/oak ridge/walnut grove	lf	770	\$	15.00	\$ 11,550	1995	50	0.76	\$	8,77
		timber ridge/redwood dr/heartland heights/salt ford rd	lf	650	\$	15.00	\$ 9,750	1998	50	0.82	\$	7,99
		seldom seen III/hunters crossing/sandstone dr	lf	2,950	\$	15.00	\$ 44,250	1999	50	0.84	\$	37,17
		southpoint condos	lf	1,350	\$	15.00	\$ 20,250	2000	50	0.86	\$	17.41
		brookstone	lf .	780	\$	15.00	\$ 11,700	2002	50	0.90	\$	10,53
		banberry	lf	360	\$	15.00		2002	50	0.90	\$	4,86
		park place	lf	1,180	\$	15.00		2003	50	0.92	\$	16,28
	I and the second	jenny lynne	lf	2,860	\$	15.00		2003	50	0.92	\$	39,46
		ingham mills/hekk dev	if if	370	\$	15.00		2003	50	0.72	\$	5,10
				1,022		15.00		2003	50	0.72	\$	14,10
		hawley heights dr	lf ''		\$							
		rodeo's restaurant	lf		\$	15.00		2004	50	0.94	\$	16,92
	Ë	bunkum dr	lf	1,431	\$	15.00		2005	50	0.96	\$	20,60
	Force Mains	jamison place condo	lf	675	\$	15.00	\$ 10,125	2005	50	0.96	\$	9,72
	- To	2.5" force main										
	2	brightwood/maple ridge/oak ridge/walnut grove	lf lf	3,395	\$	15.00	\$ 50,925	1995	50	0.76	\$	38,70
	l £	3" force main			i							
		DHMC force main	lf	8,336	\$	20.00	\$ 166,720	1991	50	0.68	\$	113,37
		bright ridge	lf	4,986	\$	20,00	\$ 99,720	1993	50	0.72	\$	71,79
		seldom seen and brightwood	lf	8,760	\$	20.00	\$ 175,200	1994	50	0.74	\$	129,64
		brightwood/maple ridge/oak ridge/walnut grove	lf		\$	20.00		1995	50	0.76	\$	9,88
		timber ridge/redwood dr/heartland heights/salt ford rd	lf If		\$		\$ 51,000	1998	50	0.82	\$	41,820
		park place	 if	2,475	\$	20.00		2003	50	0.92	\$	45,54
		4" force main	 "	2,475	ΙΨ-	20.00	Ψ 47,300	2003	30	0.72	ΙΨ	40,04
			1,5	2,480	4	25.00	\$ 62,000	1993	50	0.72	\$	44,64
		mt meadows	lf ''		\$							
		seldom seen and brightwood	lf 17	8,760	\$		\$ 219,000	1994	50	0.74	\$	162,06
	1	timber ridge/redwood dr/heartland heights/salt ford rd	lf lf		\$		\$ 121,250	1998	50	0.82	\$	99,42
		cumberland dr	lf		\$		\$ 67,800	2000	50	0.86	\$	58,30
		saltfork to brightwood dr	lf	1,254	\$	25.00	\$ 31,350	2002	50	0.90	\$	28,21
		6" force main										
		old orchard/apple blossom	lf	4,540	\$	35.00		2002	50	0.90	\$	143,01
		brookstone	lf	4,100	\$	35.00	\$ 143,500	2002	50	0.90	\$	129,15
						·						
	100 PM	SUB-TOTAL COLLECTION SYSTEM	0.000		175.484	0.50	\$ 7,823,735				\$	6,133,58
	The Street Stree	[1987 WWTP - 20,000 gpd Capacity (see attached worksheet)	LS	1	\$	240,000		1987	20	0.00	\$	
		Main Lab & Blower Building (Approximately 50' x 30')	1	1	\$	225,000		1994	20	0.35	\$	78,75
			 	 	10	420,000	4 کری ۱۹۵۰ ک	1/74	<u> </u>	0.33	 "	70,70
		Headworks	 	ļ <u>-</u>	-	005.000	A 005.000	0007		0.05	 	210.55
		Raw Sewage Pump Station (includes wet well/valve pit/pumps/rails/controls		1	\$	225,000		2006	20	0.95	\$	213,75
		Building		1	\$	10,000	\$ 10,000	1994	20	0.35	\$	3,50
		Screening										
		Mechanically Cleaned Bar Screens		1	\$		\$ 100,000	2006	20	0.95	\$	95,00
		Manual Bar Screen		1	\$	40,000	\$ 40,000	1994	20	0.35	\$	14,00

TABLE 1: CURRENT REPLACEMENT COST

20,000 gpd plant 100,000 gpd plant 200,000 gpd expansion (300,000 gpd capacity) 180,000 gpd expansion (480,000 gpd capacity)

Phase 1 1987 Phase 2 1990 Phase 3 1994 Phase 4 2006

	It .	1								Total Est.
		Unit	quantity							Current Val \$ 1,
	Processing (Sequential Batch Reactors: SBR's)	 	<u> </u>		3,000	\$ 0,000	1774	20	0,33	1,
	Controls	Unit Quantity 2007 Replacement Total Cost Total	\$ 95,							
	Flow Splitter Box									
	Actuated Flow Control Valves	 	1				New York New York			
	Tanks	<u> </u>		Φ	100,000	\$ 100,000	2000	Design Life (years) Remainin	0,73	φ /5,
	Two [2] @ 57 ft long x 24 ft wide x 16.5 ft high (inside dim.)		-	4	227 200	¢ 22/ 500	100/	20	0.25	\$ 78,
	Two (2) @ 57 ft long x 24 ft wide x 16.5 ft high (inside dim.)									
		 								
	Blowers Diffusers	 		Φ	150,000	φ 150,000	1774	20	0.33	- J2
	Dinusers		ļ <u> </u>	<u></u>	97.000	¢ 07.000	1007	20	0.25	\$ 30
	<u> </u>	-	1							
		 	<u> </u>	<u> </u>	00,000	\$ 66,000	2006	20	0.75) D
	<u>Decanters</u>	ļ			50,000	<i>t</i> 50,000	1007		0.05	4 45
			1							
5		ļ	1	\$	50,000	\$ 50,000	2006	20	0,95	\$ 47
₹	Stainless Steel Air Piping	 			10.000	¢ /6.000	100/		0.05	\$ 14
WASTEWATER TREATMENT PLANT			1							
E			1 1	\$	40,000	\$ 40 <u>,000</u>	2006	20	0.95	\$ 38
a di	Sluage Pumps & Controls	 			05.000	A 05 000	100/		0.05	<u> </u>
Σ		ļ	1							\$ 8
TA .			1	\$	25,000	\$ 25,000	2006	20	0.95	\$ 23
₩,	RAS/WAS Flow Splitter Boxes									
Ľ ⊢							otal Cost Installed Life (years) Remaining Curr 5,000 1994 20 0.35 \$ 100,000 2006 20 0.95 \$ 5,000 1994 20 0.35 \$ 100,000 2006 20 0.95 \$ 224,500 1994 20 0.35 \$ 224,500 2006 20 0.95 \$ 86,000 1994 20 0.35 \$ 86,000 2006 20 0.95 \$ 50,000 1994 20 0.35 \$ 50,000 1994 20 0.35 \$ 40,000 1994 20 0.35 \$ 40,000 1994 20 0.35 \$ 25,000 1994 20 0.35 \$ 25,000 1994 20 0.35 \$ 5,000 2006 20 0.95 \$			
Œ		ļ	1	\$	5,000	\$ 5,000	2006	20	0.95	\$ 4
#	Sludge Pumps & Controls RAS/WAS Flow Splitter Boxes Disinfection (Chlorination/Dechlorination) Tank 1 (One {1} @ 20 ft long x 21.5 ft wide x 10.5 ft high (inside dim.)) Tank 2 (One {1} @ 30 ft long x 30 ft wide x 8 ft high (inside dim.)) Building Over Tank 2 (30 feet x 30 feet) Chlor/Dechlor Equipment Effluent Pumps & Controls Post Aeration (Cascade Aeration) Flow Metering Sludge Processing									
			11							\$.
益		L	1							\$ '
- T										
₹			1	\$						
S	Effluent Pumps & Controls	İ	1	\$	25,000	\$ 25,000				
	Post Aeration (Cascade Aeration)		1	\$	10,000	\$ 10,000	1994	20	0.35	\$
	Flow Metering		1 .	\$	15,000	\$ 15,000	2006	20	0.95	\$ 1
	Sludge Processing									
	Aerobic Digesters									
	Tanks (Two (2) @ 39 ft long x 13 ft wide x 16.5 ft high (inside dim.))		1	\$			1990			
	Blowers		1	\$	30,000	\$ 30,000			0.15	\$
	Blowers	1					1994	20	0.35	\$ 2
	Diffusers		1	\$	80,000	\$ 80,000	1994	20	0,35	\$ 2
	Stainless Steel Air Piping		1	\$	20,000	\$ 20,000	1994	20	0.35	\$
	Sludge Transfer Pumps & Controls									
	Belt Filter Press w/sump & Controls	1					2002			
	Belt Filter Press Sludge Pump & Controls	1					2002		0.75	
	Studge Coneyor & Controls									
	Roll-Off Container								0.75	
	Building	T								
	Non-Potable Water System	1								
	Laboratory Equipment	 								
	Site fencing, access drives, and landscaping	l								
	Plant Piping									
	Plant Electrical	 								
	Standby Power	 								
	SUB-TOTAL WASTEWATER TREATMENT PLANT	22.00.00.00.00		*						
LAND		SINCE MEDICAL STREET	CHICAMOSTAL AND LONG SEC.	\$				N. 1944 - A. 1945 - S. 1944 - S. 1945 - S	entes artes desartes establicas (1900)	22 3010000000000000000000000000000000000
LAIN			, , ,							\$ 8,195

CARACAS.

CAL-2. Table 2 – Original Cost (Handy-Whitman Original Cost)

TABLE 2: ORIGINAL COST

Phase 1 1987 Phase 2 1990 Phase 3 1994 Phase 4 2006

Calculation of original cost using the Handy-Whitman Index 20,000 gpd plant 100,000 gpd plant 200,000 gpd expansion (300,000 gpd capacity) 180,000 gpd expansion (480,000 gpd capacity)

1				2007 Replacement	2007 Replacement	Year	HW Index	HW Index	Total Est.	Useful Life	Accumulated	Original Cost
	ltem	Unit	Quantity	Unit Cost Data	Total Cost	Installed	Year Installed	2007	Original Cost	Remaining	Depreciation \$ 9,558	Net of Depr \$ 3,717
	Lift Station #1 - Picnic Woods/Big Water Dr/Apple Ct - 2 hp	ls	1 1	\$ 25,000 \$ 30,000		1989 1993	296 334	007	\$ 13,275 \$ 17,978	0.28	\$ 9,558 10,068	
	Lift Station #2 - Bright Ridge Pump Station - 5 hp Lift Station #3 - Pontiac/Carr Rd - 5 hp	ls ls		\$ 30,000 \$ 30,000		1995	374		\$ 20,135	0.52	9,665	
	Lift Station #3 - Pontiac/Carr Rd - 5 np Lift Station #4 - Lamplight/Picnic Wood Sec 10 - 2 hp	ls		\$ 25,000		1996	381		\$ 17,116	0.56	7,531	
l Barrier	Lift Station #4 - Lamptignt/Fichic Wood Sec 10 - 2 hp Lift Station #5 - Provident Development Downtown to American State Bank - 2	ls		\$ 25,000		1997	396	557	\$ 17,790	0.60	7,116	
l lass as a last	Lift Station #6 - Timber Ridge/Redwood Dr/Heartland Heights/Salt Ford Rd - 5	ls		\$ 30,000		1998	402		\$ 21,671	0.64	7,802	
Liff Stattons	Lift Station #7 - Seldom Seen III/Hunters Crossing/Sandstone Dr - 5 hp	ls		\$ 30,000		1999	415		\$ 22,345	0.68	7,150	15,195
	Lift Station #8 - Southpoint Condo's - 5 hp	ls		\$ 30,000		2000	431	557	\$ 23,235	0.72	6,506	16,729
<u>5</u>	Lift Station #9 - Old Orchard/Apple Blossom - 40 hp	ls	1	\$ 100,000		2002	444	557	\$ 79,784	0.80	15,957	63,827
	Lift Station #10 - Brookstone - 20 hp	ls	1	\$ 80,000	\$ 80,000	2002	444	557	\$ 63,827	0.80	12,765	51,062
	Lift Station #11 - Brookstone - 2 hp	ls	1	\$ 25,000		2002	444		\$ 19,946	0.80	3,989	
l ki T	Lift Station #12 - Saltfork to Brightwood Dr - 7 hp	ls	1	\$ 45,000		2002	444		\$ 35,903	0.80	7,181	
I I	Lift Station #13 - Park Place - 7 hp	ls	1	\$ 45,000		2003	462		\$ 37,358		5,977	
	Lift Station #14 - Ingham Mills/Hekk Dev - 5 hp	ls	1	\$ 30,000		2003	462		\$ 24,906		3,985	
	Lift Station #15 - Jamison Place Condo - 3 hp	ls	1	\$ 25,000	\$ 25,000	2005	519	557	\$ 23,315	0.92	1,865	21,450
	4" pipe											
L	timber ridge/redwood dr/heartland heights/salt ford rd	lf	2,900	\$ 25.00	\$ 72,500	1998	206	357	\$ 41,835	0.82	7,530	34,304
L	8" pipe (average 7' depth)					1000	4.72	055	2 255 (44		10.077	00.077
	picnic woods dr, jamison dr to picnic woods dr, main to plant	lf	7,023	\$ 50.00		1987	158		\$ 155,411	0.60	62,164 14,813	
	picnic woods/renck ct/siefferman ct	lf 16		\$ 50.00		1988	196 213		\$ 38,980 \$ 237,582	0.62	85,529	
	picnic woods/big water dr/apple ct	lf lf	7,964 3,670	\$ 50.00 \$ 50.00		1989 1990	213		\$ 237,582 \$ 104.857	0.66	35,651	69,206
	picnic woods/gabbard/gibson/vineyard	lf		\$ 50.00		1991	191		\$ 24,236	0.68	7,756	
	cedar ridge	if		\$ 50.00		1992	174		\$ 135,374	0.70	40,612	
I I	picnic woods/judd/strother bright ridge	lf	7.669	\$ 50.00		1993	184		\$ 197,632	0.72	55,337	
	lela	If				1993	184		\$ 84,011	0.72	23,523	
I Indiana I	seldom seen and brightwood	- If				1994	182		\$ 223,294	0.74	58,056	
	pontiac/carr rd	lf				1995	196		\$ 74,310	0.76	17,834	
ewest Vilveria	lamplight/picnic wood sec 10	lf		\$ 50.00		1996	202		\$ 41,022	0.78	9,025	31,997
8	christian church/bright vet	Lf		\$ 50.00	\$ 70,750	1996	202	357	\$ 40,032	0.78	8,807	31,225
	picnic woods sec 10	lf	2,285	\$ 50.00	\$ 114,250	1997	207	357	\$ 66,246	0.80	13,249	
F	provident development downtown bright to american state bank	lf	1,066	\$ 50.00		1997	207		\$ 30,905	0.80	6,181	24,724
6	bright business center	lf		\$ 50.00		1997	207		\$ 54,069	0.80	10,814	43,255
	timber ridge/redwood dr/heartland heights/salt ford rd	lf	2,975			1998	206		\$ 85,833	0.82	15,450	
l karanaan E	seldom seen ill/hunters crossing/sandstone dr	lf	2,061			1999	207		\$ 59,752	0.84	9,560	
	southpoint condos	lf		\$ 50.00		2000	217		\$ 89,657	0.86	12,552	
l la la L	grote/trading post	lf		\$ 50.00		2000	217		\$ 6,686	0.86	936	
	trade line	lf		\$ 50.00		2000	217		\$ 22,794	0.86	3,191	19,603 350,123
L	old orchard/apple blossom	Lf		\$ 50.00		2002	237		\$ 389,025	0.90	38,903 33,127	
l le L	brookstone	Lf	.,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	\$ 50.00		2002	237		\$ 331,269 \$ 33,193	0.90	33,127	
	dawn paul dr/grubbs 3	lf If		\$ 50.00 \$ 50.00		2002	237		\$ 33,193 \$ 72,395	0.90	7,239	
	saltfork to brightwood dr	Lf Lf		\$ 50.00		2002	247		\$ 217,180	0.92	17,374	
- I	park place ingham mills/hekk dev	Lf		\$ 50.00		2003	247		\$ 692	0.92	55	
 	jamison place condo	Lf		\$ 50.00		2005	270		\$ 83,193	0.96	3,328	
SYSTEM	picnic woods dr. jamison dr to picnic woods dr, main to plant	ea		\$ 2,000.00		1987	158		\$ 17.703	0.60	7,081	10,622
[S]	picnic woods/renck ct/siefferman ct	ea		\$ 2,000.00		1988	196		\$ 4,392	0.62	1,669	
S	picnic woods/big water dr/apple ct	ea		\$ 2,000.00		1989	213		\$ 23,866	0.64	8,592	15,274
Z -	picnic woods/gabbard/gibson/vineyard	ea		\$ 2,000.00		1990	204		\$ 8,000	0.66	2,720	
COLLECTION	cedar ridge	ea				1991	191		\$ 3,210	0.68	1,027	2,183
	seldom seen and brightwood	ea		\$ 2,000.00	\$ 46,000	1994	182		\$ 23,451	0.74	6,097	
	pontiac/carr rd	ea		\$ 2,000.00		1995	196		\$ 7,686	0.76	1,845	
6 F	lamplight/picnic wood sec 10	ea		\$ 2,000.00		1996	202		\$ 13,580	0.78	2,988	
	christian church/bright vet	ea		\$ 2,000.00		1996	202		\$ 7,922	0.78	1,743	
WASTEWATER	provident development downtown bright to american state bank	ea		\$ 2,000.00		1997	207		\$ 8,118	0.80	1,624	
	bright business center	ea		\$ 2,000.00		1997	207		\$ 23,193	0.80	4,639	18,555
≥ 5	seldom seen III/hunters crossing/sandstone dr	ea		\$ 2,000.00		1999	207		\$ 8,118	0.84	1,299	
	southpoint condos	ea		\$ 2,000.00		2000	217		\$ 8,510	0.86	1,191	7,318
& L	grote/trading post	ea	3	\$ 2,000.00		2000	217	•••	\$ 3,647	0.86	511	
j ≩ L	trade line	ea		\$ 2,000.00		2000	217		\$ 2,431	0.86	340 4,780	
	old orchard/apple blossom	ea		\$ 2,000.00		2002	237		\$ 47,798	0.90		
L	brookstone	ea		\$ 2,000.00		2002	237		\$ 30,538	0.90	3,054 531	
L	dawn paul dr/grubbs 3	ea		\$ 2,000.00		2002	237		\$ 5,311	0.90	929	
	saltfork to brightwood dr	ea		\$ 2,000.00		2002	237		\$ 9,294 \$ 27.675	0.90 0.92	2,214	
	park place	ea		\$ 2,000.00 \$ 2,000.00		2003	247		\$ 27,675 \$ 10,588	0.92	424	
	jamison place condo 1,5" force main	ea		\$ 2,000.00	\$ 14,000	2005	2/0	35/	<u>φ ιυ,588</u>	0.70	424	10,163
				,			. 7					i
	lamplight/picnic wood sec 10	14	1.500	\$ 15.00	\$ 22,500	1996	202	357	\$ 12,731	0.78	2,801	9,930

TABLE 2: ORIGINAL COST

Calculation of original cost using the Handy-Whitman Index 20,000 gpd plant 100,000 gpd plant 200,000 gpd expansion (300,000 gpd capacity) 180,000 gpd expansion (480,000 gpd capacity)

Phase 1 1987 Phase 2 1990 Phase 3 1994 Phase 4 2006

	ltem	Unit	Quantity	2007 Replacement Unit Cost Data	2007 Replacement Total Cost	Year Installed	HW Index Year Installed	HW Index 2007	Total Est. Original Cost	Useful Life Remaining	Accumulated Depreciation	Original Cost Net of Depr
	2" force main											
	mt meadows	lf	1,720	\$ 15.00		1993	184	357	\$ 13,297	0.72	3,723	9,574
	pontiac/carr rd	lf	1,640			1995	196	357	\$ 13,506	0.76	3,241	10,264
	brightwood/maple ridge/oak ridge/walnut grove	Lf	770	\$ 15.00		1995	196	357	\$ 6,341	0.76	1,522	4,819
	timber ridge/redwood dr/heartland heights/salt ford rd	Lf	650	\$ 15.00		1998	206	357	\$ 5,626	0.82	1,013	4,613
	seldom seen III/hunters crossing/sandstone dr	Lf Lf	2,950 1,350			1999 2000	207 217	357 357	\$ 25,658 \$ 12,309	0.84	4,105	21,552 10,586
	southpoint condos	lf UT		\$ 15.00 \$ 15.00		2000	237		\$ 12,309 \$ 7,767	0.86	1,723 777	6,991
	brookstone banberry	lf	360	\$ 15.00		2002	237	357	\$ 3,585	0.90	358	3,226
	park place	lf lf	1,180	\$ 15.00		2002	247	357	\$ 12,246	0.92	980	11,267
	jenny lynne	lf lf	2,860	\$ 15.00		2003	247		\$ 29,682	0.92	2,375	27,307
	ingham mills/hekk dev	lf	370	\$ 15.00		2003	247		\$ 3,840	0.92	307	3,533
	hawley heights dr	if	1,022	\$ 15.00		2003	247		\$ 10,606	0.92	849	9,758
	rodeo's restaurant	Lf .	1,200	\$ 15.00		2004	250		\$ 12,605	0.94	756	11,849
2	bunkum dr	lf	1,431	\$ 15.00	\$ 21,465	2005	270		\$ 16,234	0.96	649	15,585
Mains	jamison place condo	lf	675	\$ 15.00	\$ 10,125	2005	270	357	\$ 7,658	0.96	306	7,351
2 0	2.5" force main											
Force	brightwood/maple ridge/oak ridge/walnut grove	l f	3,395	\$ 15.00	\$ 50,925	1995	196	357	\$ 27,959	0.76	6,710	21,249
L	3" force main											
	DHMC force main	l (8,336	\$ 20.00	\$ 166,720	1991	191	357	\$ 89,198	0.68	28,543	60,654
	bright ridge	lf	4,986	\$ 20.00		1993	184		\$ 51,396	0.72	14,391	37,005
	seldom seen and brightwood	lf	8,760	\$ 20.00	\$ 175,200	1994	182	357	\$ 89,318	0.74	23,223	66,095
16.00	brightwood/maple ridge/oak ridge/walnut grove	lf	650	\$ 20.00	\$ 13,000	1995	196		\$ 7,137	0.76	1,713	5,424
	timber ridge/redwood dr/heartland heights/salt ford rd	lf	2,550	\$ 20.00	\$ 51,000	1998	206		\$ 29,429	0.82	5,297	24,131
	park place	Lf	2,475	\$ 20.00	\$ 49,500	2003	247	357	\$ 34,248	0.92	2,740	31,508
	4" force main	lf .	2 (00	\$ 25.00	\$ 62,000	1993	184	357	\$ 31,955	0.72	0.077	23,008
	mt meadows seldom seen and brightwood	Lf	2,480 8,760	\$ 25.00		1993	182		\$ 111,647	0.74	8,947 29,028	82,619
	timber ridge/redwood dr/heartland heights/salt ford rd	if if	4,850	\$ 25.00		1998	206		\$ 69,965	0.82	12,594	57,371
	cumber hoge/redwood dr/nearttand neights/satt ford re	lf	2,712	\$ 25.00		2000	217		\$ 41,212	0.86	5,770	35,442
	saltfork to brightwood dr	lf (1,254	\$ 25.00		2002	237		\$ 20,812	0.90	2,081	18,731
	6" force main	- "	1,204	J 25.00	ψ 31,330	2002	237	337	Φ 20,012	0.70	2,001	10,731
	old orchard/apple blossom	lf.	4,540	\$ 35.00	\$ 158,900	2002	237	357	\$ 105,488	0.90	10,549	94,939
	brookstone	lf	4,100	\$ 35.00		2002	237		\$ 95,265	0.90	9,526	85,738
			1								,,,,,,	
0/21/00/99/00/47				E28170-375-0103-01090-3717-1717-1715-308	Water and the state of the state of the state of	and the second returned of the property	BORRESON COMMUNICATION CONTRACT					
	SUB-TOTAL COLLECTION SYSTEM	77-31-A1-77-54-0	1.000 PM A	AND EXPLOYED AND SOCIAL SECTION AND ADDRESS OF THE PARTY	\$ 7,823,735	RECORDED TO COME			\$ 4,673,801		\$ 960,927	\$ 3,712,874
Transplanta Carrette	1987 WWTP - 20,000 gpd Capacity (see attached worksheet)	LS	1	\$ 240,000	\$ 240,000	1987	257	486	\$ 126,797	0.00	126,797	0
Rosson and Conference	1987 WWTP - 20,000 gpd Capacity [see attached worksheet] Main Lab & Blower Building [Approximately 50' x 30']	LS	1	\$ 240,000 \$ 225,000		1987 1994	257 295	486		0.00 0.35		\$ 3,712,874 0 49,011
1022251331133105530	1997 WWTP - 20,000 gpd Capacity [see attached worksheet] Main Lab & Blower Building [Approximately 50" x 30"] Headworks	LS		\$ 225,000	\$ 240,000 \$ 225,000	1994	295	486 474	\$ 126,797 \$ 140,032	0.35	126,797 91,021	0 49,011
100000000000000000000000000000000000000	1987 WWTP - 20,000 gpd Capacity [see attached worksheet] Main Lab & Blower Building [Approximately 50' x 30'] Headworks Raw Sewage Pump Station [includes wet well/valve pit/pumps/rails/controls	LS	1	\$ 225,000 \$ 225,000	\$ 240,000 \$ 225,000 \$ 225,000	1994 2006	295 482	486 474 497	\$ 126,797 \$ 140,032 \$ 218,209	0.35 0.95	126,797 91,021 10,910	0 49,011 207,299
10000000	1987 WWTP - 20,000 gpd Capacity [see attached worksheet] Main Lab & Blower Building [Approximately 50' x 30'] Headworks Raw Sewage Pump Station [includes wet well/valve pit/pumps/rails/controls Building	LS		\$ 225,000	\$ 240,000 \$ 225,000 \$ 225,000	1994	295	486 474 497	\$ 126,797 \$ 140,032	0.35	126,797 91,021	0 49,011
TO SECURE A SECURE	1987 WWTP - 20,000 gpd Capacity [see attached worksheet] Main Lab & Blower Building [Approximately 50" x 30"] Headworks Raw Sewage Pump Station (includes wet well/valve pit/pumps/rails/controls Building Screening	LS	1	\$ 225,000 \$ 225,000 \$ 10,000	\$ 240,000 \$ 225,000 \$ 225,000 \$ 10,000	1994 2006 1994	295 482 295	486 474 497 474	\$ 126,797 \$ 140,032 \$ 218,209 \$ 6,224	0.35 0.95 0.35	126,797 91,021 10,910 4,045	0 49,011 207,299 2,178
To an order to the design of t	1987 WWTP - 20,000 gpd Capacity [see attached worksheet] Main Lab & Blower Building [Approximately 50' x 30'] Headworks Raw Sewage Pump Station [includes wet well/valve pit/pumps/rails/controls Building Screening Mechanically Cleaned Bar Screens	LS	1	\$ 225,000 \$ 225,000 \$ 10,000 \$ 100,000	\$ 240,000 \$ 225,000 \$ 225,000 \$ 10,000 \$ 100,000	1994 2006 1994 2006	295 482 295 482	486 474 497 474 497	\$ 126,797 \$ 140,032 \$ 218,209 \$ 6,224 \$ 96,982	0.35 0.95 0.35	126,797 91,021 10,910 4,045 4,849	0 49,011 207,299 2,178 92,133
To constant a subsequent	1987 WWTP - 20,000 gpd Capacity [see attached worksheet] Main Lab & Blower Building [Approximately 50' x 30'] Headworks Raw Sewage Pump Station [includes wet well/valve pit/pumps/rails/controls Building Screening Mechanically Cleaned Bar Screens Manual Bar Screen	LS	1 1 1	\$ 225,000 \$ 225,000 \$ 10,000 \$ 100,000 \$ 40,000	\$ 240,000 \$ 225,000 \$ 225,000 \$ 10,000 \$ 100,000 \$ 40,000	2006 1994 2006 1994	295 482 295 482 328	486 474 497 474 497 497	\$ 126,797 \$ 140,032 \$ 218,209 \$ 6,224 \$ 96,982 \$ 26,398	0.35 0.95 0.35 0.95 0.35	126,797 91,021 10,910 4,045 4,849 17,159	0 49,011 207,299 2,178 92,133 9,239
The contract of the contract o	1987 WWTP - 20,000 gpd Capacity [see attached worksheet] Main Lab & Blower Building [Approximately 50' x 30'] Headworks Raw Sewage Pump Station lincludes wet well/valve pit/pumps/rails/controls Building Screening Mechanically Cleaned Bar Screens Manual Bar Screen Building Building	LS	1	\$ 225,000 \$ 225,000 \$ 10,000 \$ 100,000	\$ 240,000 \$ 225,000 \$ 225,000 \$ 10,000 \$ 100,000 \$ 40,000	1994 2006 1994 2006	295 482 295 482	486 474 497 474 497 497	\$ 126,797 \$ 140,032 \$ 218,209 \$ 6,224 \$ 96,982	0.35 0.95 0.35	126,797 91,021 10,910 4,045 4,849	0 49,011 207,299 2,178 92,133
To constant a substantial	1987 WWTP - 20,000 gpd Capacity [see attached worksheet] Main Lab & Blower Building [Approximately 50' x 30'] Headworks Raw Sewage Pump Station [includes wet well/valve pit/pumps/rails/controls Building Screening Mechanically Cleaned Bar Screens Manual Bar Screen Building Processing [Sequential Batch Reactors: SBR's]	LS	1 1 1 1 1	\$ 225,000 \$ 225,000 \$ 10,000 \$ 100,000 \$ 40,000 \$ 5,000	\$ 240,000 \$ 225,000 \$ 225,000 \$ 10,000 \$ 40,000 \$ 5,000	2006 1994 2006 1994 2006 1994 1994	482 295 482 295 482 328 295	486 474 497 474 497 497 497	\$ 126,797 \$ 140,032 \$ 218,209 \$ 6,224 \$ 96,982 \$ 26,398 \$ 3,112	0.35 0.95 0.35 0.95 0.35 0.35	126,797 91,021 10,910 4,045 4,849 17,159 2,023	0 49,011 207,299 2,178 92,133 9,239 1,089
	1987 WWTP - 20,000 gpd Capacity [see attached worksheet] Main Lab & Blower Building [Approximately 50' x 30'] Headworks Raw Sewage Pump Station [includes wet well/valve pit/pumps/rails/controls Building Screening Mechanically Cleaned Bar Screens Manual Bar Screen Building Processing [Sequential Batch Reactors: SBR's] Controls	LS	1 1 1	\$ 225,000 \$ 225,000 \$ 10,000 \$ 100,000 \$ 40,000 \$ 5,000	\$ 240,000 \$ 225,000 \$ 10,000 \$ 100,000 \$ 40,000 \$ 5,000 \$ 100,000	2006 1994 2006 1994 2006 1994 1994 2006	295 482 295 482 328 295	486 474 497 474 497 497 474 497	\$ 126,797 \$ 140,032 \$ 218,209 \$ 6,224 \$ 96,982 \$ 26,398 \$ 3,112 \$ 96,982	0.35 0.95 0.35 0.95 0.35 0.35 0.35	126,797 91,021 10,910 4,045 4,849 17,159 2,023	92,133 92,139 92,139 92,139 92,133 92,139 1,089
To constant a subsequent	1987 WWTP - 20,000 gpd Capacity [see attached worksheet] Main Lab & Blower Building [Approximately 50' x 30'] Headworks Raw Sewage Pump Station [includes wet well/valve pit/pumps/rails/controls Building Screening Mechanically Cleaned Bar Screens Manual Bar Screen Building Processing [Sequential Batch Reactors: SBR's] Controls Flow Splitter Box	LS	1 1 1 1 1	\$ 225,000 \$ 225,000 \$ 10,000 \$ 100,000 \$ 40,000 \$ 5,000 \$ 5,000	\$ 240,000 \$ 225,000 \$ 10,000 \$ 100,000 \$ 40,000 \$ 5,000 \$ 100,000 \$ 5,000	2006 1994 2006 1994 2006 1994 1994 2006 1994	295 482 295 482 328 295 482 328 295	486 474 497 474 497 497 474 497 497	\$ 126,797 \$ 140,032 \$ 218,209 \$ 6,224 \$ 96,982 \$ 26,398 \$ 3,112 \$ 96,982 \$ 3,300	0.35 0.95 0.35 0.95 0.35 0.35 0.35 0.35	126,797 91,021 10,910 4,045 4,849 17,159 2,023 4,849 2,145	0 49,011 207,299 2,178 92,133 9,239 1,089 92,133 1,155
	1987 WWTP - 20,000 gpd Capacity [see attached worksheet] Main Lab & Blower Building [Approximately 50' x 30'] Headworks Raw Sewage Pump Station [includes wet well/valve pit/pumps/rails/controls Building Screening Mechanically Cleaned Bar Screens Manual Bar Screen Building Processing [Sequential Batch Reactors: SBR's] Controls Flow Splitter Box Actuated Flow Control Valves	LS	1 1 1 1 1	\$ 225,000 \$ 225,000 \$ 10,000 \$ 100,000 \$ 40,000 \$ 5,000	\$ 240,000 \$ 225,000 \$ 10,000 \$ 100,000 \$ 40,000 \$ 5,000 \$ 100,000 \$ 5,000	2006 1994 2006 1994 2006 1994 1994 2006	295 482 295 482 328 295	486 474 497 474 497 497 474 497 497	\$ 126,797 \$ 140,032 \$ 218,209 \$ 6,224 \$ 96,982 \$ 26,398 \$ 3,112 \$ 96,982	0.35 0.95 0.35 0.95 0.35 0.35 0.35	126,797 91,021 10,910 4,045 4,849 17,159 2,023	92,133 92,139 92,139 92,139 92,133 92,139 1,089
	1987 WWTP - 20,000 gpd Capacity [see attached worksheet] Main Lab & Blower Building [Approximately 50' x 30'] Headworks Raw Sewage Pump Station (includes wet well/valve pit/pumps/rails/controls Building Screening Mechanically Cleaned Bar Screens Manual Bar Screen Building Processing [Sequential Batch Reactors: SBR's] Controls Flow Splitter Box Actuated Flow Control Valves Tanks	LS	1 1 1 1 1	\$ 225,000 \$ 225,000 \$ 10,000 \$ 100,000 \$ 40,000 \$ 5,000 \$ 100,000 \$ 100,000 \$ 100,000	\$ 240,000 \$ 225,000 \$ 10,000 \$ 100,000 \$ 40,000 \$ 5,000 \$ 100,000 \$ 5,000 \$ 100,000	2006 1994 2006 1994 2006 1994 1994 2006 1994 2006	295 482 295 482 328 295 482 328 482 328 482	486 474 497 477 497 497 474 497 497 497	\$ 126,797 \$ 140,032 \$ 218,209 \$ 6,224 \$ 96,982 \$ 26,378 \$ 3,112 \$ 96,982 \$ 3,300 \$ 96,982	0.35 0.95 0.35 0.95 0.35 0.35 0.35 0.95 0.95 0.95	126,797 91,021 10,910 4,045 4,849 17,159 2,023 4,849 2,145 4,849	0 49,011 207,299 2,178 92,133 9,239 1,089 92,133 1,155 92,133
	1987 WWTP - 20,000 gpd Capacity [see attached worksheet] Main Lab & Blower Building [Approximately 50' x 30'] Headworks Raw Sewage Pump Station [includes wet well/valve pit/pumps/rails/controls Building Screening Mechanically Cleaned Bar Screens Manual Bar Screen Building Processing [Sequential Batch Reactors: SBR's] Controls Flow Splitter Box Actuated Flow Control Valves Tanks Two [2] @ 57 ft long x 24 ft wide x 16.5 ft high [inside dim.]	LS	1 1 1 1 1	\$ 225,000 \$ 225,000 \$ 10,000 \$ 100,000 \$ 40,000 \$ 5,000 \$ 100,000 \$ 100,000 \$ 224,500	\$ 240,000 \$ 225,000 \$ 10,000 \$ 100,000 \$ 40,000 \$ 5,000 \$ 100,000 \$ 5,000 \$ 100,000	2006 1994 2006 1994 2006 1994 2006 1994 2006	295 482 295 482 328 295 482 328 482 328 482 329 482	486 4774 497 4774 497 497 474 497 497 497	\$ 126,797 \$ 140,032 \$ 218,209 \$ 6,224 \$ 96,982 \$ 3,3112 \$ 96,982 \$ 3,300 \$ 96,982 \$ 139,720	0.35 0.95 0.35 0.95 0.35 0.35 0.35 0.95 0.35 0.95 0.35	126,797 91,021 10,910 4,045 4,849 17,159 2,023 4,849 2,145 4,849 90,818	0 49.011 207,299 2.178 92,133 9.239 1.089 92,133 1,155 92,133
	1987 WWTP - 20,000 gpd Capacity [see attached worksheet] Main Lab & Blower Building [Approximately 50' x 30'] Headworks Raw Sewage Pump Station (includes wet well/valve pit/pumps/rails/controls Building Screening Mechanically Cleaned Bar Screens Manual Bar Screen Building Processing [Sequential Batch Reactors: SBR's] Controls Flow Splitter Box Actuated Flow Control Valves Tanks	LS	1 1 1 1 1	\$ 225,000 \$ 225,000 \$ 10,000 \$ 100,000 \$ 40,000 \$ 5,000 \$ 100,000 \$ 5,000 \$ 224,500 \$ 224,500	\$ 240,000 \$ 225,000 \$ 10,000 \$ 100,000 \$ 40,000 \$ 5,000 \$ 100,000 \$ 100,000 \$ 5,000 \$ 224,500	2006 1994 2006 1994 2006 1994 1994 2006 1994 2006	295 482 295 482 328 295 482 328 482 328 482 328 482 328 482 328	486 474 497 474 497 497 474 497 497 497 497	\$ 126,797 \$ 140,032 \$ 218,209 \$ 6,224 \$ 96,982 \$ 26,398 \$ 3,112 \$ 96,982 \$ 3,390 \$ 96,982 \$ 139,720 \$ 213,133	0.35 0.95 0.35 0.95 0.35 0.35 0.95 0.95 0.95 0.95 0.95 0.95	126,797 91,021 10,910 4,045 4,849 17,159 2,023 4,849 2,145 4,849 90,818 10,657	0 49.011 207.299 2.178 92.133 9.239 1.089 92.133 1.155 92.133 48.902 202.476
	1987 WWTP - 20,000 gpd Capacity [see attached worksheet] Main Lab & Blower Building [Approximately 50' x 30'] Headworks Raw Sewage Pump Station [includes wet well/valve pit/pumps/rails/controls Building Screening Mechanically Cleaned Bar Screens Manual Bar Screen Building Processing [Sequential Batch Reactors: SBR's] Controls Flow Splitter Box Actuated Flow Control Valves Tanks Two [2] @ 57 ft long x 24 ft wide x 16.5 ft high [inside dim.] Two [2] @ 57 ft long x 24 ft wide x 16.5 ft high [inside dim.] Blowers	LS	1 1 1 1 1	\$ 225,000 \$ 225,000 \$ 10,000 \$ 100,000 \$ 40,000 \$ 5,000 \$ 100,000 \$ 100,000 \$ 224,500 \$ 224,500	\$ 240,000 \$ 225,000 \$ 10,000 \$ 100,000 \$ 40,000 \$ 5,000 \$ 100,000 \$ 100,000 \$ 5,000 \$ 224,500	2006 1994 2006 1994 2006 1994 2006 1994 2006	295 482 295 482 328 295 482 328 482 328 482 329 482	486 474 497 474 497 497 474 497 497 497 497	\$ 126,797 \$ 140,032 \$ 218,209 \$ 6,224 \$ 96,982 \$ 26,398 \$ 3,112 \$ 96,982 \$ 3,300 \$ 96,982 \$ 139,720 \$ 213,133	0.35 0.95 0.35 0.95 0.35 0.35 0.35 0.95 0.35 0.95 0.35	126,797 91,021 10,910 4,045 4,849 17,159 2,023 4,849 2,145 4,849 90,818	0 49.011 207,299 2.178 92,133 9.239 1.089 92,133 1,155 92,133
To contrast it shipshops	1987 WWTP - 20,000 gpd Capacity [see attached worksheet] Main Lab & Blower Building [Approximately 50' x 30'] Headworks Raw Sewage Pump Station [includes wet well/valve pit/pumps/rails/controls Building Screening Mechanically Cleaned Bar Screens Manual Bar Screen Building Processing [Sequential Batch Reactors: SBR's] Controls Flow Splitter Box Actuated Flow Control Valves Tanks Two [2] @ 57 ft long x 24 ft wide x 16.5 ft high [inside dim.] Two [2] @ 57 ft long x 24 ft wide x 16.5 ft high [inside dim.]	LS	1 1 1 1 1	\$ 225,000 \$ 225,000 \$ 10,000 \$ 100,000 \$ 40,000 \$ 5,000 \$ 100,000 \$ 5,000 \$ 224,500 \$ 224,500	\$ 240,000 \$ 225,000 \$ 10,000 \$ 100,000 \$ 40,000 \$ 5,000 \$ 100,000 \$ 100,000 \$ 5,000 \$ 224,500	2006 1994 2006 1994 2006 1994 1994 2006 1994 2006	295 482 295 482 328 295 482 328 482 328 482 328 482 328 482 328	486 4774 497 4774 497 497 474 497 497 497 4	\$ 126,797 \$ 140,032 \$ 218,209 \$ 6,224 \$ 96,982 \$ 26,398 \$ 3,112 \$ 96,982 \$ 3,390 \$ 96,982 \$ 139,720 \$ 213,133	0.35 0.95 0.35 0.95 0.35 0.35 0.95 0.95 0.95 0.95 0.95 0.95	126,797 91,021 10,910 4,045 4,849 17,159 2,023 4,849 2,145 4,849 90,818 10,657	0 49,011 207,299 2,178 92,133 9,239 1,089 92,133 1,155 92,133 48,902 202,476 34,648
	1987 WWTP - 20,000 gpd Capacity [see attached worksheet] Main Lab & Blower Building [Approximately 50' x 30'] Headworks Raw Sewage Pump Station [includes wet well/valve pit/pumps/rails/controls Building Screening Mechanically Cleaned Bar Screens Manual Bar Screen Building Processing [Sequential Batch Reactors: SBR's] Controls Flow Splitter Box Actuated Flow Control Valves Tanks Two [2] @ 57 ft long x 24 ft wide x 16.5 ft high [inside dim.] Two [2] @ 57 ft long x 24 ft wide x 16.5 ft high [inside dim.] Blowers	LS	1 1 1 1 1	\$ 225,000 \$ 225,000 \$ 10,000 \$ 100,000 \$ 40,000 \$ 5,000 \$ 100,000 \$ 5,000 \$ 224,500 \$ 224,500 \$ 150,000	\$ 240,000 \$ 225,000 \$ 225,000 \$ 10,000 \$ 100,000 \$ 40,000 \$ 5,000 \$ 100,000 \$ 100,000 \$ 224,500 \$ 224,500 \$ 150,000	2006 1994 2006 1994 2006 1994 1994 2006 1994 2006 1994 2006	295 482 295 482 328 295 482 328 482 482 295 450 328	486 474 497 474 497 497 497 497 497 497 497	\$ 126,797 \$ 140,032 \$ 218,209 \$ 6,224 \$ 96,982 \$ 26,398 \$ 3,112 \$ 96,982 \$ 139,720 \$ 139,720 \$ 213,133 \$ 98,994	0.35 0.95 0.35 0.95 0.35 0.35 0.95 0.35 0.95 0.35 0.95 0.35	126,797 91,021 10,910 4,045 4,849 17,159 2,023 4,849 2,145 4,849 90,818 10,657 64,346	0 49,011 207,299 2,178 92,133 9,239 1,089 92,133 1,155 92,133 48,902 202,476 34,648
	1987 WWTP - 20,000 gpd Capacity [see attached worksheet] Main Lab & Blower Building [Approximately 50' x 30'] Headworks Raw Sewage Pump Station [includes wet well/valve pit/pumps/rails/controls Building Screening Mechanically Cleaned Bar Screens Manual Bar Screen Building Processing [Sequential Batch Reactors: SBR's] Controls Flow Splitter Box Actuated Flow Control Valves Tanks Two [2] @ 57 ft long x 24 ft wide x 16.5 ft high [inside dim.] Two [2] @ 57 ft long x 24 ft wide x 16.5 ft high [inside dim.] Blowers	LS	1 1 1 1 1	\$ 225,000 \$ 225,000 \$ 10,000 \$ 100,000 \$ 40,000 \$ 5,000 \$ 100,000 \$ 100,000 \$ 224,500 \$ 150,000 \$ 224,500 \$ 86,000	\$ 240,000 \$ 225,000 \$ 10,000 \$ 10,000 \$ 40,000 \$ 5,000 \$ 100,000 \$ 100,000 \$ 224,500 \$ 224,500 \$ 150,000	2006 1994 2006 1994 2006 1994 1994 2006 1994 2006 1994 2006 1994	295 482 295 482 328 295 482 328 482 328 482 328 482 328 482 328 328	486 474 497 497 497 497 497 497 497 497 497	\$ 126,797 \$ 140,032 \$ 218,209 \$ 6,224 \$ 96,982 \$ 26,398 \$ 3,112 \$ 96,982 \$ 3,300 \$ 96,982 \$ 139,720 \$ 213,133 \$ 98,994	0.35 0.95 0.35 0.95 0.35 0.35 0.95 0.95 0.95 0.95 0.35 0.95 0.35 0.95	126,797 91,021 10,910 4,045 4,849 17,159 2,023 4,849 2,145 4,849 90,818 10,657 64,346	0 49,011 207,299 2,178 92,133 9,239 1,089 92,133 1,155 92,133 48,902 202,476 34,648
	1987 WWTP - 20,000 gpd Capacity [see attached worksheet] Main Lab & Blower Building [Approximately 50' x 30'] Headworks Raw Sewage Pump Station [includes wet well/valve pit/pumps/rails/controls Building Screening Mechanically Cleaned Bar Screens Manual Bar Screen Building Processing [Sequential Batch Reactors: SBR's] Controls Flow Splitter Box Actuated Flow Control Valves Tanks Two [2] @ 57 ft long x 24 ft wide x 16.5 ft high [inside dim.] Two [2] @ 37 ft long x 24 ft wide x 16.5 ft high [inside dim.] Blowers Diffusers	LS	1 1 1 1	\$ 225,000 \$ 225,000 \$ 10,000 \$ 10,000 \$ 40,000 \$ 5,000 \$ 100,000 \$ 100,000 \$ 224,500 \$ 224,500 \$ 150,000 \$ 36,000 \$ 36,000 \$ 50,000 \$ 50,000	\$ 240,000 \$ 225,000 \$ 100,000 \$ 100,000 \$ 40,000 \$ 5,000 \$ 100,000 \$ 100,000 \$ 100,000 \$ 100,000 \$ 100,000 \$ 100,000 \$ 224,500 \$ 224,500 \$ 224,500 \$ 36,000 \$ 36,000 \$ 36,000	1994 2006 1994 2006 1994 1994 2006 1994 2006 1994 2006 1994 2006 1994 1994 2006	295 482 295 482 328 275 482 328 482 328 482 295 450 328 482 328 328	486 4774 497 497 497 497 497 497 497 497 49	\$ 126,797 \$ 140,032 \$ 218,209 \$ 6,224 \$ 96,982 \$ 26,398 \$ 3,112 \$ 96,982 \$ 139,720 \$ 139,720 \$ 213,133 \$ 98,994 \$ 56,757 \$ 83,404 \$ 32,998	0.35 0.95 0.35 0.95 0.35 0.35 0.95 0.35 0.95 0.35 0.95 0.95 0.95 0.95 0.95 0.95	126,797 91,021 10,910 4,045 4,849 17,159 2,023 4,849 2,145 4,849 90,818 10,657 64,346	0 49.011 207.299 2,178 92,133 9,239 1,089 92,133 1,155 92,133 48,902 202.476 34,648 19,865 79,234
	1987 WWTP - 20,000 gpd Capacity [see attached worksheet] Main Lab & Blower Building [Approximately 50' x 30'] Headworks Raw Sewage Pump Station [includes wet well/valve pit/pumps/raits/controls Building Screening Mechanically Cleaned Bar Screens Manual Bar Screen Building Processing [Sequential Batch Reactors: SBR's] Controls Flow Splitter Box Actuated Flow Control Valves Tanks Two [2] @ 57 ft long x 24 ft wide x 16.5 ft high [inside dim.] Two [2] @ 57 ft long x 24 ft wide x 16.5 ft high [inside dim.] Blowers Diffusers	LS	1 1 1 1	\$ 225,000 \$ 225,000 \$ 10,000 \$ 100,000 \$ 40,000 \$ 5,000 \$ 5,000 \$ 100,000 \$ 5,000 \$ 100,000 \$ 224,500 \$ 224,500 \$ 36,000 \$ 86,000	\$ 240,000 \$ 225,000 \$ 100,000 \$ 100,000 \$ 40,000 \$ 5,000 \$ 100,000 \$ 100,000 \$ 100,000 \$ 100,000 \$ 100,000 \$ 100,000 \$ 224,500 \$ 224,500 \$ 224,500 \$ 36,000 \$ 36,000 \$ 36,000	1994 2006 1994 2006 1994 1994 2006 1994 2006 1994 2006 1994 2006 1994 2006	295 482 295 482 328 295 482 328 482 295 482 295 482 295 480 295 480 295	486 474 497 497 497 497 497 497 497 497 497	\$ 126,797 \$ 140,032 \$ 218,209 \$ 6,224 \$ 96,982 \$ 26,398 \$ 3,112 \$ 96,982 \$ 139,720 \$ 133,133 \$ 98,994 \$ 33,404	0.35 0.95 0.35 0.95 0.35 0.35 0.95 0.35 0.95 0.35 0.95 0.35 0.95 0.35 0.95	126,797 91,021 10,910 4,045 4,849 17,159 2,023 4,849 2,145 4,849 90,818 10,657 64,346 36,892 4,170	0 49.011 207.299 2.178 92.133 9.239 1.089 92.133 1.155 92.133 48.902 202.476 34.648 19.865 79.234
ANT	1987 WWTP - 20,000 gpd Capacity [see attached worksheet] Main Lab & Blower Building [Approximately 50' x 30'] Headworks Raw Sewage Pump Station [includes wet well/valve pit/pumps/rails/controls Building Screening Mechanically Cleaned Bar Screens Manual Bar Screen Building Processing [Sequential Batch Reactors: SBR's] Controls Flow Splitter Box Actuated Flow Control Valves Tanks Two [2] @ 57 ft long x 24 ft wide x 16.5 ft high [inside dim.] Two [2] @ 37 ft long x 24 ft wide x 16.5 ft high [inside dim.] Blowers Diffusers	LS	1 1 1 1	\$ 225,000 \$ 225,000 \$ 10,000 \$ 10,000 \$ 40,000 \$ 5,000 \$ 5,000 \$ 100,000 \$ 5,000 \$ 224,500 \$ 224,500 \$ 224,500 \$ 36,000 \$ 50,000 \$ 50,000	\$ 240,000 \$ 225,000 \$ 10,000 \$ 10,000 \$ 40,000 \$ 5,000 \$ 100,000 \$ 5,000 \$ 100,000 \$ 150,000 \$ 224,500 \$ 224,500 \$ 36,000 \$ 36,000	1994 2006 1994 2006 1994 1994 2006 1994 2006 1994 2006 1994 2006 1994 2006 1994 2006	295 482 295 482 328 295 482 328 482 295 482 328 482 328 482	486 4774 497 497 497 497 497 497 497 497 49	\$ 126,797 \$ 140,032 \$ 218,209 \$ 6,224 \$ 96,982 \$ 26,398 \$ 3,112 \$ 96,982 \$ 139,720 \$ 213,133 \$ 98,994 \$ 56,757 \$ 83,404 \$ 32,998 \$ 48,491	0.35 0.95 0.35 0.95 0.35 0.35 0.35 0.35 0.35 0.35 0.95 0.95 0.35 0.95 0.95 0.35 0.95 0.95	126,797 91,021 10,910 4,045 4,849 17,159 2,023 4,849 2,145 4,849 90,818 10,657 64,346 36,892 4,170 21,449 2,425	0 49,011 207,299 2,178 92,133 9,239 1,089 92,133 1,155 92,133 48,902 202,476 34,648 19,865 79,234
PLANT	1987 WWTP - 20,000 gpd Capacity [see attached worksheet] Main Lab & Blower Building [Approximately 50' x 30'] Headworks Raw Sewage Pump Station [includes wet well/valve pit/pumps/raits/controls Building Screening Mechanically Cleaned Bar Screens Manual Bar Screen Building Processing [Sequential Batch Reactors: SBR's] Controls Flow Splitter Box Actuated Flow Control Valves Tanks Two [2] @ 57 ft long x 24 ft wide x 16.5 ft high [inside dim.] Two [2] @ 57 ft long x 24 ft wide x 16.5 ft high [inside dim.] Blowers Diffusers	LS	1 1 1 1	\$ 225,000 \$ 10,000 \$ 10,000 \$ 10,000 \$ 40,000 \$ 5,000 \$ 100,000 \$ 100,000 \$ 100,000 \$ 224,500 \$ 224,500 \$ 150,000 \$ 36,000 \$ 50,000 \$ 40,000 \$ 40,000 \$ 224,500 \$ 150,000 \$ 36,000 \$ 40,000 \$ 40,000 \$ 40,000	\$ 240,000 \$ 225,000 \$ 10,000 \$ 10,000 \$ 40,000 \$ 5,000 \$ 100,000 \$ 5,000 \$ 100,000 \$ 5,000 \$ 15,000 \$ 224,500 \$ 150,000 \$ 86,000 \$ 86,000 \$ 40,000	1994 2006 1994 2006 1994 1994 2006 1994 2006 1994 2006 1994 2006 1994 2006 1994 2006	295 482 295 482 328 275 482 328 462 328 482 328 482 328 482 328 328	486 477 497 497 497 497 497 497 497 497 497	\$ 126,797 \$ 140,032 \$ 218,209 \$ 6,224 \$ 96,982 \$ 26,398 \$ 3,112 \$ 96,982 \$ 139,720 \$ 139,720 \$ 139,720 \$ 213,133 \$ 96,982 \$ 23,404 \$ 34,404 \$ 32,998 \$ 32,998 \$ 48,491 \$ 426,398	0.35 0.95 0.35 0.95 0.35 0.35 0.95 0.35 0.95 0.35 0.95 0.95 0.35 0.95 0.95 0.35 0.95 0.35 0.95	126,797 91,021 10,910 4,045 4,849 17,159 2,023 4,849 2,145 4,849 90,818 10,657 64,346 4,346 4,346 4,346 2,145 4,346 4,34	0 49.011 207.299 2.178 92.133 9.239 1.089 92.133 1.155 92.133 48.902 202.476 34.648 19.865 79.234
T PLANT	1987 WWTP - 20,000 gpd Capacity [see attached worksheet] Main Lab & Blower Building [Approximately 50' x 30'] Headworks Raw Sewage Pump Station [includes wet well/valve pit/pumps/raits/controls Building Screening Mechanically Cleaned Bar Screens Manual Bar Screen Building Processing [Sequential Batch Reactors: SBR's] Controls Flow Splitter Box Actuated Flow Control Valves Tanks Two [2] @ 57 ft long x 24 ft wide x 16.5 ft high [inside dim.] Two [2] @ 57 ft long x 24 ft wide x 16.5 ft high [inside dim.] Blowers Diffusers Decanters Staintess Steel Air Piping	LS	1 1 1 1	\$ 225,000 \$ 225,000 \$ 10,000 \$ 10,000 \$ 40,000 \$ 5,000 \$ 5,000 \$ 100,000 \$ 5,000 \$ 224,500 \$ 224,500 \$ 224,500 \$ 36,000 \$ 50,000 \$ 50,000	\$ 240,000 \$ 225,000 \$ 10,000 \$ 10,000 \$ 40,000 \$ 5,000 \$ 100,000 \$ 5,000 \$ 100,000 \$ 5,000 \$ 15,000 \$ 224,500 \$ 150,000 \$ 86,000 \$ 86,000 \$ 40,000	1994 2006 1994 2006 1994 1994 2006 1994 2006 1994 2006 1994 2006 1994 2006 1994 2006	295 482 295 482 328 295 482 328 482 295 482 328 482 328 482	486 477 497 497 497 497 497 497 497	\$ 126,797 \$ 140,032 \$ 218,209 \$ 6,224 \$ 96,982 \$ 26,398 \$ 3,112 \$ 96,982 \$ 139,720 \$ 213,133 \$ 98,994 \$ 56,757 \$ 83,404 \$ 32,998 \$ 48,491	0.35 0.95 0.35 0.95 0.35 0.35 0.35 0.35 0.35 0.35 0.95 0.95 0.35 0.95 0.95 0.35 0.95 0.95	126,797 91,021 10,910 4,045 4,849 17,159 2,023 4,849 2,145 4,849 90,818 10,657 64,346 36,892 4,170 21,449 2,425	0 49,011 207,299 2,178 92,133 9,239 1,089 92,133 1,155 92,133 48,902 202,476 34,648 19,865 79,234
ENT PLANT	1987 WWTP - 20,000 gpd Capacity [see attached worksheet] Main Lab & Blower Building [Approximately 50' x 30'] Headworks Raw Sewage Pump Station [includes wet well/valve pit/pumps/raits/controls Building Screening Mechanically Cleaned Bar Screens Manual Bar Screen Building Processing [Sequential Batch Reactors: SBR's] Controls Flow Splitter Box Actuated Flow Control Valves Tanks Two [2] @ 57 ft long x 24 ft wide x 16.5 ft high [inside dim.] Two [2] @ 57 ft long x 24 ft wide x 16.5 ft high [inside dim.] Blowers Diffusers	LS	1 1 1 1	\$ 225,000 \$ 225,000 \$ 10,000 \$ 10,000 \$ 40,000 \$ 5,000 \$ 5,000 \$ 100,000 \$ 5,000 \$ 100,000 \$ 224,500 \$ 224,500 \$ 224,500 \$ 36,000 \$	\$ 240,000 \$ 225,000 \$ 10,000 \$ 100,000 \$ 40,000 \$ 5,000 \$ 100,000 \$ 100,000 \$ 5,000 \$ 100,000 \$ 5,000 \$ 224,500 \$ 224,500 \$ 224,500 \$ 3,000 \$ 3,000 \$ 3,000 \$ 3,000 \$ 40,000 \$ 40,000 \$ 40,000 \$ 40,000 \$ 40,000 \$ 40,000 \$ 40,000	1994 2006 1994 2006 1994 1994 1994 2006 1994 2006 1994 2006 1994 2006 1994 2006 1994 2006	295 482 295 482 328 295 482 328 482 295 482 328 482 328 482	486 477 497 497 497 497 497 497 497 497 497	\$ 126,797 \$ 140,032 \$ 218,209 \$ 6,224 \$ 96,982 \$ 26,398 \$ 3,112 \$ 96,982 \$ 139,720 \$ 131,333 \$ 96,982 \$ 33,404 \$ 243,404 \$ 34,404 \$ 32,998 \$ 38,793	0.35 0.95 0.35 0.95 0.35 0.35 0.35 0.35 0.35 0.35 0.95 0.35 0.95 0.35 0.95 0.35 0.95 0.35 0.95 0.35 0.95	126,797 91,021 10,910 4,045 4,849 17,159 2,023 4,849 2,145 4,849 90,818 10,657 64,346 36,892 4,170 21,449 2,425 17,159	0 49,011 207,299 2,178 92,133 9,239 1,089 92,133 1,155 92,133 48,902 202,476 34,648 19,845 79,234 46,066 9,239 36,853
MENT PLANT	1987 WWTP - 20,000 gpd Capacity [see attached worksheet] Main Lab & Blower Building [Approximately 50' x 30'] Headworks Raw Sewage Pump Station [includes wet well/valve pit/pumps/raits/controls Building Screening Mechanically Cleaned Bar Screens Manual Bar Screen Building Processing [Sequential Batch Reactors: SBR's] Controls Flow Splitter Box Actuated Flow Control Valves Tanks Two [2] @ 57 ft long x 24 ft wide x 16.5 ft high [inside dim.] Two [2] @ 57 ft long x 24 ft wide x 16.5 ft high [inside dim.] Blowers Diffusers Decanters Staintess Steel Air Piping	LS	1 1 1 1	\$ 225,000 \$ 225,000 \$ 10,000 \$ 100,000 \$ 40,000 \$ 5,000 \$ 100,000 \$ 5,000 \$ 100,000 \$ 224,500 \$ 224,500 \$ 36,000 \$ 36,000 \$ 40,000 \$ 40,000 \$ 50,000 \$ 50,000 \$ 50,000	\$ 240,000 \$ 225,000 \$ 100,000 \$ 100,000 \$ 100,000 \$ 40,000 \$ 5,000 \$ 100,000 \$ 5,000 \$ 224,500 \$ 224,500 \$ 224,500 \$ 36,000 \$ 36,000	1994 2006 1994 2006 1994 2006 1994 2006 1994 2006 1994 2006 1994 2006 1994 2006 1994 2006	295 482 295 482 328 295 482 328 482 328 482 295 450 328 462 328 462 328 462 328 328 328	486 477 497 497 497 497 497 497 497	\$ 126,797 \$ 140,032 \$ 218,209 \$ 6,224 \$ 96,982 \$ 3,112 \$ 96,982 \$ 3,300 \$ 96,982 \$ 139,720 \$ 213,133 \$ 98,994 \$ 33,404 \$ 34,404 \$ 32,998 \$ 48,491 \$ 48,491 \$ 48,491 \$ 16,499	0.35 0.95 0.35 0.95 0.35 0.95 0.35 0.95 0.35 0.95 0.35 0.95 0.35 0.95 0.35 0.95 0.35 0.95 0.35	126,797 91,021 10,910 4,045 4,849 17,159 2,023 4,849 2,145 4,849 90,818 10,857 64,346 4,770 2,145 4,770 10,724	0 49.011 207.299 2.178 92.133 9.239 1.089 92.133 1.155 92.133 48.902 202.476 34.648 19.865 79.234 46.066 9.239 36.853
ATMENT PLANT	1987 WWTP - 20,000 gpd Capacity [see attached worksheet] Main Lab & Blower Building [Approximately 50' x 30'] Headworks Raw Sewage Pump Station [includes wet well/valve pit/pumps/raits/controls Building Screening Mechanically Cleaned Bar Screens Manual Bar Screen Building Processing [Sequential Batch Reactors: SBR's] Controls Flow Splitter Box Actuated Flow Control Valves Tanks Two [2] @ 57 ft long x 24 ft wide x 16.5 ft high [inside dim.] Two [2] @ 57 ft long x 24 ft wide x 16.5 ft high [inside dim.] Blowers Diffusers Decanters Stainless Steel Air Piping Sludge Pumps & Controls	LS	1 1 1 1	\$ 225,000 \$ 225,000 \$ 10,000 \$ 10,000 \$ 40,000 \$ 5,000 \$ 5,000 \$ 100,000 \$ 5,000 \$ 100,000 \$ 224,500 \$ 224,500 \$ 224,500 \$ 36,000 \$	\$ 240,000 \$ 225,000 \$ 10,000 \$ 100,000 \$ 40,000 \$ 5,000 \$ 100,000 \$ 100,000 \$ 5,000 \$ 100,000 \$ 5,000 \$ 224,500 \$ 224,500 \$ 224,500 \$ 3,000 \$ 3,000 \$ 3,000 \$ 3,000 \$ 40,000 \$ 40,000 \$ 40,000 \$ 40,000 \$ 40,000 \$ 40,000 \$ 40,000	1994 2006 1994 2006 1994 1994 1994 2006 1994 2006 1994 2006 1994 2006 1994 2006 1994 2006	295 482 295 482 328 295 482 328 482 295 482 328 482 328 482	486 477 497 497 497 497 497 497 497 497 497	\$ 126,797 \$ 140,032 \$ 218,209 \$ 6,224 \$ 96,982 \$ 26,398 \$ 3,112 \$ 96,982 \$ 139,720 \$ 131,333 \$ 96,982 \$ 33,404 \$ 243,404 \$ 34,404 \$ 32,998 \$ 38,793	0.35 0.95 0.35 0.95 0.35 0.35 0.35 0.35 0.35 0.35 0.95 0.35 0.95 0.35 0.95 0.35 0.95 0.35 0.95 0.35 0.95	126,797 91,021 10,910 4,045 4,849 17,159 2,023 4,849 2,145 4,849 90,818 10,657 64,346 36,892 4,170 21,449 2,425 17,159	0 49,011 207,299 2,178 92,133 9,239 1,089 92,133 1,155 92,133 48,902 202,476 34,648 19,845 79,234 46,066 9,239 36,853
REATMENT PLANT	1987 WWTP - 20,000 gpd Capacity [see attached worksheet] Main Lab & Blower Building [Approximately 50' x 30'] Headworks Raw Sewage Pump Station [includes wet well/valve pit/pumps/raits/controls Building Screening Mechanically Cleaned Bar Screens Manual Bar Screen Building Processing [Sequential Batch Reactors: SBR's] Controls Flow Splitter Box Actuated Flow Control Valves Tanks Two [2] @ 57 ft long x 24 ft wide x 16.5 ft high [inside dim.] Two [2] @ 57 ft long x 24 ft wide x 16.5 ft high [inside dim.] Blowers Diffusers Decanters Staintess Steel Air Piping	LS	1 1 1 1	\$ 225,000 \$ 225,000 \$ 10,000 \$ 10,000 \$ 40,000 \$ 5,000 \$ 100,000 \$ 5,000 \$ 100,000 \$ 224,500 \$ 224,500 \$ 224,500 \$ 36,000 \$	\$ 240,000 \$ 225,000 \$ 100,000 \$ 100,000 \$ 40,000 \$ 5,000 \$ 100,000 \$ 5,000 \$ 100,000 \$ 100,000 \$ 100,000 \$ 5,000 \$ 224,500 \$ 224,500 \$ 150,000 \$ 86,000 \$ 50,000 \$ 50,000 \$ 50,000 \$ 25,000 \$ 25,000 \$ 25,000	1994 2006 1994 2006 1994 1994 2006 1994 2006 1994 2006 1994 2006 1994 2006 1994 2006 1994 2006 1994 2006	295 482 295 482 328 295 482 328 482 328 482 328 482 328 482	486 477 497 497 497 497 497 497 497	\$ 126,797 \$ 140,032 \$ 218,209 \$ 6,224 \$ 96,982 \$ 26,398 \$ 3,112 \$ 96,982 \$ 139,720 \$ 139,720 \$ 213,133 \$ 98,994 \$ 33,404 \$ 32,996 \$ 48,491 \$ 26,398 \$ 38,793 \$ 16,499 \$ 24,245	0.35 0.95 0.35 0.95 0.35 0.35 0.35 0.95 0.35 0.95 0.35 0.95 0.35 0.95 0.35 0.95 0.35 0.95 0.35 0.95	126,797 91,021 10,910 4,045 4,849 17,159 2,023 4,849 2,145 4,849 90,818 10,657 64,346 34,892 4,170 21,449 2,425 17,159 1,940	0 49,011 207,299 2,178 92,133 1,165 92,133 1,155 92,133 48,902 202,476 34,648 11,549 46,066 9,239 36,853 5,775 23,033
R TREATMENT PLANT	1987 WWTP - 20,000 gpd Capacity [see attached worksheet] Main Lab & Blower Building [Approximately 50' x 30'] Headworks Raw Sewage Pump Station [includes wet well/valve pit/pumps/raits/controls Building Screening Mechanically Cleaned Bar Screens Manual Bar Screen Building Processing [Sequential Batch Reactors: SBR's] Controls Flow Splitter Box Actuated Flow Control Valves Tanks Two [2] @ 57 ft long x 24 ft wide x 16.5 ft high [inside dim.] Two [2] @ 57 ft long x 24 ft wide x 16.5 ft high [inside dim.] Blowers Diffusers Decanters Stainless Steel Air Piping Sludge Pumps & Controls	LS	1 1 1 1	\$ 225,000 \$ 225,000 \$ 10,000 \$ 100,000 \$ 40,000 \$ 5,000 \$ 100,000 \$ 5,000 \$ 100,000 \$ 224,500 \$ 224,500 \$ 36,000 \$ 36,000 \$ 40,000 \$ 40,000 \$ 50,000 \$ 50,000 \$ 50,000	\$ 240,000 \$ 225,000 \$ 100,000 \$ 100,000 \$ 100,000 \$ 5,000 \$ 100,000 \$ 5,000 \$ 224,500 \$ 224,500 \$ 224,500 \$ 3,000 \$ 3,000 \$ 3,000 \$ 3,000 \$ 40,000 \$ 5,000 \$	1994 2006 1994 2006 1994 2006 1994 2006 1994 2006 1994 2006 1994 2006 1994 2006 1994 2006	295 482 295 482 328 295 482 328 482 328 482 295 450 328 462 328 462 328 462 328 328 328	486 477 497 497 497 497 497 497 497	\$ 126,797 \$ 140,032 \$ 218,209 \$ 6,224 \$ 96,982 \$ 3,112 \$ 96,982 \$ 3,300 \$ 96,982 \$ 139,720 \$ 213,133 \$ 98,994 \$ 33,404 \$ 34,404 \$ 32,998 \$ 48,491 \$ 48,491 \$ 48,491 \$ 16,499	0.35 0.95 0.35 0.95 0.35 0.95 0.35 0.95 0.35 0.95 0.35 0.95 0.35 0.95 0.35 0.95 0.35 0.95 0.35	126,797 91,021 10,910 4,045 4,849 17,159 2,023 4,849 2,145 4,849 90,818 10,857 64,346 4,770 2,145 4,770 10,724	0 49,011 207,299 2,178 92,133 9,239 1,089 92,133 1,155 92,133 48,902 202,476 34,648 19,865 79,234 46,066 9,239 36,853

TABLE 2: ORIGINAL COST

Calculation of original cost using the Handy-Whitman Index 20,000 gpd plant 100,000 gpd plant 200,000 gpd expansion (300,000 gpd capacity) 180,000 gpd expansion [480,000 gpd capacity]

Phase 1 1987 Phase 2 1990 Phase 3 1994 Phase 4 2006

		Į.		2007 Replacement	2007 Replacement	Year	HW Index	HW Index	Total Est.	Useful Life	Accumulated	Original Cost
	ltem	Unit	Quantity	Unit Cost Data	Total Cost	installed	Year Installed	2007	Original Cost	Remaining	Depreciation	Net of Depr
EWATE	Disinfection (Chlorination/Dechlorination)											
- W	Tank 1 (One (1) @ 20 ft long x 21.5 ft wide x 10.5 ft high (inside dim.))		1	\$ 36,153		1990	264	474	\$ 20,136	0.15	17,115	3,020
. a	Tank 2 (One (1) @ 30 ft long x 30 ft wide x 8 ft high (inside dim.))		1	\$ 51,667		1990	264	474	\$ 28,776	0.15	24,460	4,316
1 75	Building Over Tank 2 (30 feet x 30 feet)		1	\$ 112,500		1990	264	474	\$ 62,658	0.15	53,259	
WASTI	Chlor/Dechlor Equipment		1	\$ 50,000		2006	482	497	\$ 48,491	0.95	2,425	46,066
5	Effluent Pumps & Controls		1	\$ 25,000		1994	328	497	\$ 16,499	0.35	10,724	5,775
	Post Aeration (Cascade Aeration)		1	\$ 10,000		1994	328	497	\$ 6,600	0.35	4,290	2,310
	Flow Metering		1	\$ 15,000	\$ 15,000	2006	482	497	\$ 14,547	0.95	727	13,820
	Sludge Processing											
	Aerobic Digesters											j
	Tanks (Two (2) @ 39 ft long x 13 ft wide x 16.5 ft high (inside dim.))		1	\$ 123,500		1990	264	474	\$ 68,785	0.15	58,467	10,318
	Blowers		1	\$ 30,000		1990	299	497	\$ 18,048	0.15	15,341	2,707
	Blowers		1	\$ 75,000		1994	328	497	\$ 49,497	0.35	32,173	17,324
	Diffusers		1	\$ 80,000		1994	328	497	\$ 52,797	0.35	34,318	18,479
	Stainless Steel Air Piping		1	\$ 20,000		1994	328	497	\$ 13,199	0.35	8,579	4,620
	Sludge Transfer Pumps & Controls		1	\$ 25,000		1994	328	497	\$ 16,499	0.35	10,724	5,775
	Belt Filter Press w/sump & Controls		11	\$ 150,000		2002	414		\$ 124,950	0.75	31,237	93,712
	Belt Filter Press Sludge Pump & Controls		3	\$ 20,000		2002	414	497	\$ 16,660	0.75	4,165	12,495
The second state of the	Sludge Coneyor & Controls		1	\$ 25,000		2002	414	497	\$ 20,825	0.75	5,206	15,619
	Roll-Off Container		1	\$ 2,500		2002	414	497	\$ 2,082	0.75	521	1,562
	Building		1	\$ 10,000		2002	372	474	\$ 7,848	0.75	1,962	5,886
	Non-Potable Water System		1	\$ 5,000		1994	328	497	\$ 3,300	0.35	2,145	1,155
	Laboratory Equipment		1	\$ 35,000		2006	482	497	\$ 33,944	0.95	1,697	32,246
	Site fencing, access drives, and landscaping		1	\$ 100,000	\$ 100,000	2006	450	474	\$ 94,937	0.95	4,747	90,190
	Plant Piping		1	\$ 100,000		2006	482	497	\$ 96,982	0.95	4,849	92,133
I have been a second and	Plant Electrical		1	\$ 125,000		2006	482	497	\$ 121,227	0.95	6,061	115,166
	Standby Power		1	\$ 100,000		2006	482	497	\$ 96,982	0.95	4,849	92,133
	SUB-TOTAL WASTEWATER TREATMENT PLANT	2000年100	POSSESS		\$ 3,387,319		100000000000000000000000000000000000000		\$ 2,638,868		\$ 872,869	
LAND		acres	5	\$ 12,000					\$ 60,000			\$ 60,000
			TO	TAL ORIGINAL COST	\$ 11,271,054				\$ 7,372,669		\$ 1,833,797	\$ 5,538,873

•					
CAL-3. T	able 3 – WWTP Re	placement Cost	Using Curren	t Low Bid Co	st Information
				•	

TABLE 3: WWTP REPLACEMENT COSTS USING CURRENT LOW BID COST INFORMATION

(Wastewater Treatment Plant Only - No Collection System)

Cross check of estimate using actual cost per gallon information.

 20,000 gpd plant
 Phase 1
 1987

 100,000 gpd plant
 Phase 2
 1990

 200,000 gpd expansion (300,000 gpd capacity)
 Phase 3
 1994

 180,000 gpd expansion (480,000 gpd capacity)
 Phase 4
 2006

							теріасе	meni Cosi Le	ess Depreciation
	100 T T T T T T T T T T T T T T T T T T			2007 Replacement	2007 Replacement	Year	Design	Useful Life	Total Est.
	ltem	Unit	Quantity	Unit Cost Data	Total Cost	Installed	Life (years)	Remaining	Current Value
	1987 WWTP - 20,000 gpd Capacity - New Package Type Plant	LS	1	\$ 500,000	\$ 500,000	1987	20	0.00	\$ -
WASTEWTER	1990 WWTP Expansion - 100,000 gpd Capacity - New SBR Plant	LS	1	\$ 1,300,000	\$ 1,300,000	1990	20	0.15	\$ 195,000
TREATMENT PLANT	1994 WWTP Expansion - 300,000 gpd Capacity (200,000 gpd increase)	LS	1	\$ 1,720,000	\$ 1,720,000	1994	20	0.35	\$ 602,000
IREAIMENT PLANT	2006 WWTP Expansion - 480,000 gpd Capacity (180,000 gpd increase)	LS	1	\$ 1,548,000	\$ 1,548,000	2006	20	0.95	\$ 1,470,600
The state of the s	Sub-Total WWTP Cost - Method 2				\$ 5,068,000				\$ 2,267,600

Danis annual Coat I and Dannaistian

Refer to Table 4 and Figures 1 and 2 for unit cost determinations.

CAL-4. Table 4 – Actual WWTP Construction Costs in Indiana

TABLE 4
Actual Wastewater Treatment Plant Construction Costs in Indiana

	New Plants	Low Bid	Design Flow (MGD)	Unit Cost \$/gal	NPDES Permit #	County
1	Extended Air			····		
	Ossian	\$ 3,155,000	0.6000	\$5.26	IN0020745	Wells
	Twin Lakes RSD	\$ 4,284,000	0.3700	\$11.58	IN0062367	White
2	Oxidation Ditch					
	Milford	\$ 2,100,000	0.2500	\$8.40	IN0038318	Kosciusko
4	Package Plant					
	Western School Corp.	\$ 1,290,000	0.0498	\$25.90	IN0031801	Howard
5	Biolac					
	Taylor Township RSD	\$ 1,553,000	0.1750	\$8.87	IN0062375	Howard
6	Recirculating Media Filter					
	Sandborn	\$ 662,500	0.0660	\$10.04	IN0062685	Knox


	Plant Expansions		Low	Flow Increase	Unit Cost	NPDES	
	Plant Expansions		Bid	(MGD)	\$/gal	Permit #	County
1	Extended Air						
	Sullivan	\$	4,690,000	0.9800	\$4.79	IN0024554	Sullivan
	Lapel	\$	1,814,000	0.3600	\$5.04	IN0020087	Madison
	Pierceton	\$	1,833,000	0.4000	\$4.58	IN0020541	Kosciusko
	Noblesville (will bid on Oct. 9)	\$	20,000,000	5.0000	\$4.00	IN0020168	Hamilton
2	Oxidation Ditch						
	Danville	\$	4,656,000	0.8500	\$5.48	IN0020079	Hendricks
	Liberty	\$	4,837,000	0.4300	\$11.25	IN0020681	Union
	Clay City	\$	2,365,000	0.2420	\$9.77	IN0039861	Clay
3	SBR						
	Spencer	\$	3,698,000	0.4660	\$7.94	IN0020192	Owen
	Avon West Cent Cons. Dist.	\$	7,518,000	2.6000	\$2.89	IN0051632	Hendricks
	Washington	\$	5,995,000	1.9000	\$3.16	IN0025658	Daviess

All costs were taken from actual project bid tabs 2005 to 2007 Costs do NOT include Engineering Costs do NOT included Change Orders All flow data was taken from the EPA NPDES database CAL-5. Table 5 – Summary of Treatment Plant Results

TABLE 5
Summary of Treatment Plant Results

	Method 1 Current Replacement Cost Table 1	Method 2 Handy-Whitman Index Table 2	Method 3 Low Bid Cost Check Table 3
2007 Replacement Cost	\$3,387,319	\$3,387,319	\$5,068,000
Total Estimated Current Value or Original Cost Net of Depreciation	\$2,002,098	\$1,765,998	\$2,267,600

CAL-6. Figure 1 – New WWTP Construction Costs in Indiana



CAL-7. Figure 2 – WWTP Expansion Construction Costs in Indiana

